

UNCLASSIFIED

AD 401 157

*Reproduced
by the*

DEFENSE DOCUMENTATION CENTER

FOR

SCIENTIFIC AND TECHNICAL INFORMATION

CAMERON STATION, ALEXANDRIA, VIRGINIA



UNCLASSIFIED

NOTICE: When government or other drawings, specifications or other data are used for any purpose other than in connection with a definitely related government procurement operation, the U. S. Government thereby incurs no responsibility, nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use or sell any patented invention that may in any way be related thereto.

6.3-3-2

ASTIA
CATERGEG
AS AD NCG
401157

**DIAMOND POWER SPECIALTY CORPORATION
DIAMOND MODEL DP-3000 DURA-PORT GAGE**

**Evaluation Report
NBTL Project No. B-518
Subtask 4181
SF013-06-16
12 March 1963
by
J. ISINGER**

401157

**NAVAL BOILER AND TURBINE LABORATORY
PHILADELPHIA NAVAL SHIPYARD
PHILADELPHIA 12, PENNA.**

ASTIA
RECORDED
APR 12 1963




DIAMOND POWER SPECIALTY CORPORATION
DIAMOND MODEL DP-3000 DURA-PORT GAGE

Evaluation Report
NBTL Project No. B-518
Subtask 4181
SF013-06-16
12 March 1963
by
J. ISINGER

APPROVAL INFORMATION

Submitted by:



I. COHEN
Head
Heat Exchanger Branch



P. E. JORGENSEN
Head
Heat Power Division

Approved by:



W. W. BRALEY
Captain, USN
Director

TABLE OF CONTENTS

	<u>Page No.</u>
ABSTRACT	i
SUMMARY PAGE	ii
ADMINISTRATIVE INFORMATION	iii
REPORT OF INVESTIGATION	1
Description of Material	1
Procedure and Results	1
Introduction	1
Shock and Vibration Evaluation	2
Installation on Operating Boiler	3
Installation on Water Gage Evaluation Facility	3
Conclusions	6
Appendix I	NRL Shock and Vibration Report

LIST OF ILLUSTRATIONS

(Dura-Port) BI-Color Navy Type Water Gage Assembly Dwg. No. 103656-1056	1
Illuminator and Wide Angle Hood Assembly Dwg. No. 103657-1154	2
Photograph-Main Body of Gage	3
Photograph-Gage with Viewing Hood and Illuminator Attached	4

Tests were conducted on a pressure gauge

NBTL PROJECT B-518

ABSTRACT

A Diamond Power Specialty Corporation "Dura-Port" Gauge, designed to operate at pressures up to 3000 psig, ~~was~~ ^{was} evaluated to determine its suitability for shipboard service. The gage was first shock and vibration tested at the Naval Research Laboratory. The gage insert withstood shock and vibration tests without leakage or glass failure; the illuminator and hood assembly required modification to provide adequate shock and vibration resistance.

The gage was installed on the Laboratory's DDG-15 boiler for determination of clarity and angle of visibility. Readability of the gage, requiring reliance on the color-refraction principle, was considered satisfactory while incorporating a better than 100° viewing angle. Optimum discernment of water level was obtained at distances ten to fifteen feet from the gage.

A 256-hour full pressure test, with blowdown every forty-eight hours and a rapid pressure drop and rise every twenty-four hours, was conducted ~~on the laboratory's water-gage test facility~~ without steam leakage or mica or glass failure of the main insert. The shut-off valves showed no leakage at hand tightness during and after cooling. The leakage through the closed ball check was excessive with an average of approximately 1000 cc every 3 minutes and 10 seconds.

NBTL PROJECT B-518

SUMMARY PAGE

The Problem

Evaluate a Diamond Model DP-3000, Dura-Port Water Gauge for naval service on 1200 psi boilers. Agenda for testing was to be in accordance with revised specifications MIL-G16356B of 25 September 1961, paragraphs 4.2 through 4.2.7. and 4.5 through 4.5.6, shock and vibration tests were to be in accordance with MIL-S-901 of 19 December 1955, and MIL-S-167 of 20 December 1954, respectively.

Findings

After modifications to the gage, illuminator, and hood the entire assembly successfully withstood shock and vibration tests with the exception of light bulbs which failed during shock tests.

Evaluation of the gage on both an operating boiler and the water gage evaluation facility indicated discernment of water level was good. The gage was reliable and required little or no maintenance during several hundred hours of operation. Performance of water gage assembly valves was satisfactory with the exception that excessive leakage occurred through the closed ball check.

NBTL PROJECT B-518

ADMINISTRATIVE INFORMATION

This project was authorized by BUSHIPS ltr 9510/1-3
Ser 651D-1450 of 18 October 1961. Costs were chargeable to
Allotment 290/RDT & EN 62.2421, Budget Project 50. This is
a final report of an RDT & E project.

REPORT OF INVESTIGATION

DESCRIPTION OF MATERIALS

The ported boiler water gage submitted for evaluation was manufactured by Diamond-Power Specialty Corporation. This gage, designated as a Diamond Model DP-3000 Dura-Port Gauge, included an illuminator and wide angle hood, and was designed and built to operate at pressures up to 3000 psig. This gage was to be an improved design over the Diamond Multi-Port Gauge previously evaluated at the Laboratory under NBTL Project B-379 and found to be unsatisfactory because of glass and mica failures.

Previous dual color gages operating on the refraction principle required direct "head-on" viewing to ascertain correct water level. This was a distinct disadvantage. The subject gage was designed to provide a viewing angle of approximately 100° . Details and description of the Dura-Port gage can be obtained by referring to the drawings and photographs included as Plates 1 to 4 of this report. Information as to maintenance and operation of the gage can be obtained from the Diamond Instruction Manual, Bulletin No. 2572, of November 1961.

PROCEDURE AND RESULTS

Introduction

The Bureau of Ships authorized the Laboratory to evaluate the manufacturer's latest design Dura-Port gage according to requirements of the

NBTL PROJECT B-518

revised specifications MIL-G-16356B. Specified tests included operation on both the high pressure water gage test facility and a Laboratory 1200 psi boiler, and a complete shock and vibration evaluation.

Shock and Vibration Evaluation

Because the weight of the water gage plus its mounting exceeded the limit for the Laboratory's vibration testing machine, the Naval Research Laboratory was authorized by the Laboratory to perform both the vibration and shock tests.

While there was no leakage or glass failure during vibration tests, modifications were required to enable the complete gage assembly to meet requirements. The single expansion loop at the top of the gage was replaced with a double, symmetrical loop arrangement, shortening the radius of the loop, producing a more vibration resistant construction in this area; the sides of the wide angle viewing hood were strengthened; other modifications were made to the gage, illuminator and hood. After incorporation of all modifications, the complete assembly successfully passed the vibration requirements of MIL-STD-167 (Ships) for all frequencies between 0 and 33 cps and in each of the three principal directions of vibration.

The gage proper and the wide angle viewing hood and its lens successfully withstood the shock tests, but the function of

NBTL PROJECT B-518

the illuminator was impaired because its light bulbs failed and the glass lenses cracked and/or broke.

A complete description of the procedure and results of the shock and vibration tests are presented in Appendix I, the Naval Research Laboratory's report on the tests.

Installation on Operating Boiler

After shock and vibration tests, the gage was installed on the Laboratory's DDG-15 boiler for determination of clarity and angle of visibility and simplicity of installation.

Although the sharpest designation of water level was had at distances between ten and fifteen feet of the gage, readability, dependent upon the two-color or light refraction principle, was satisfactory with close ups from four to six feet. Difficulty was experienced while mounting the insert to the already assembled bottom valve; the small metal sealing gasket was dislodged from its position on the surface of the raised face of the valve flange. The result of this was considerable steam leakage and a damaged raised face.

Installation on Water Gage Evaluation Facility

The gage was installed on the Laboratory's high pressure water gage testing facility and subjected to a series of rapid

NBTL PROJECT B-518

pressure drops and rises, blowdowns, and pressures and temperatures and water conditions representative of those encountered in current naval power plants. Operation was conducted for 256 hours at full pressure of 1250 psig with blowdown every 48 hours and a rapid pressure drop and rise every 24 hours. A 1000 hour evaluation of the gage was not completed because of reports of successful operation aboard USS SARATOGA (CVA 60).

The gage illuminator assembly functioned satisfactorily throughout the total operating time. No leaks occurred at the port assemblies, no mica or glass failures occurred, and no maintenance was required. Three light bulb failures occurred. Visibility or discernment of water level was good, with a better than 100° viewing angle on the DDG-15 boiler; the distant views were the best. Some difficulty was encountered in replacing burned out light bulbs due to heat from the main insert and the bulb assembly. Gage valve operation was satisfactory, with no leakage through either the steam, water or drain valves during and after cooling and throughout the securing tests. The ball check rose readily, requiring approximately 58.6 lbs. per hour of escaping saturated steam. The seating ability of the ball check, however, was not satisfactory.

NBTL PROJECT B-518

allowing an average leakage of approximately 1000 cc every three minutes and ten seconds, well above the allowable leakage stated in specification MIL-G-16356B, paragraph 3.12.7.2.

During the initial steam and water shut-off valve hot cycling operation, the handwheel torques required for tight valve closure averaged 20 lb. ft. Further valve cycling produced slight packing leaks that were stopped by tightening the gland follower just enough to prevent leakage. Following the gland tightening, valve cycling operation was resumed and it was disclosed that increased handwheel torques were now required for tight valve closure. Torques up to 40 lb. ft. and 35 lb. ft. were necessary for tight closure and subsequent re-opening, respectively. These torques are above the 15 lb. ft. allowable stated in specification MIL-G-16356B, paragraphs 3.10.2 and 3.10.3.

CONCLUSIONS


Performance of the gage proper and illuminator during observation and operating test indicated adequate reliability for service use.

The illuminator, required for proper water level indication, is adequate from a shock and vibration standpoint; determination of clarity and angle of visibility was satisfactory although there is still room for improvement for close up views of four to five feet from the gage.


The main gage insert possessed advantages, namely in its light weight and ease in changing parts; however, care must be used in the assembly of the main insert to the bottom water valve, to avoid dislodging the small sealing gasket.

The ball check valve was closed by 58.6 lbs per hour of escaping saturated steam, which is below the required flow rate. The seating ability of the ball check was unsatisfactory, allowing an average leakage of approximately 1000 cc every three minutes and ten seconds.

Although the shut-off valve operation was satisfactory with no leakage throughout the securing tests, as stated on page 4, it was determined that the handwheel torques required for tight closure and re-opening ranged between 20 and 40 lb. ft.



1



LIST OF MATERIAL - QUANTITIES FOR ONE RH. ASS'Y. & ONE

PC. NO.	NAME	QTY.	MATERIAL	MAT'L SPEC.	MANUFACTURER'S NAME	DWG. NO.	BUSHIPS DWG. NO.	UNIT WT/LB.	STD. STG.
UPPER VALVE ASSEMBLIES									
1	UPPER VALVE ASSY	1	SEE DETAIL	DPSC	102416-4037				
2	CONNECTOR BODY	1	CARBON ST.	MIL-S-20000	DPSC	102419-0114			
3	LOOP-EXPANSION	1	CARBON ST.	MIL-S-20000	DPSC	102597-0112			
4	FLANGE-LOOP	1	CARBON ST.	MIL-S-20000	DPSC	102474-0112			
5	SEMI-GLIDE	1	CARBON ST.	MIL-S-20000	DPSC	102488-0112			
6	GUIDE-EXPANSION	1	CARBON ST.	MIL-S-20000	DPSC	102417-0114			
7	1/8 HEX HD BOLT 3/8	4	STEEL	A191	DPSC	102428-1112			
8	1/8 HEX NUT	4	STEEL	A191	DPSC	102429-1110			
9	GASKET 1/2" ID, 1/2" TH	1	ASBESTOS	COMPL.	DPSC	904840-0001			
10									
11									
12									
LOWER VALVE ASSEMBLIES									
13	LOWER VALVE ASSY (SEE DETAIL)	1	SEE DETAIL	DPSC	102426-4024				
14	LOWER VALVE ASSY (SEE DETAIL)	1	SEE DETAIL	DPSC	102426-4024				
15	NIPPLE-SHRODD	1	CARBON ST.	MIL-S-20000	DPSC	102393-0114			
16	FLANGE-DRAIN	1	CARBON ST.	MIL-S-20000	DPSC	102392-0117			
17	CONNECTOR BODY	1	CARBON ST.	MIL-S-20000	DPSC	102376-1112			
18	EXTENSIBLE-BALL	1	STAINLESS	A192	DPSC	102379-1112			
19	GASKET 1/2" ID, 1/2" TH	1	ASBESTOS	COMPL.	DPSC	904840-0001			
20	DIA BALL CHECK	1	STAINLESS	A192	DPSC	102748-0111			
21	1/8 HEX HD BOLT 3/8	4	STEEL	A191	DPSC	102428-1110			
22	1/8 HEX NUT	4	STEEL	A191	DPSC	102429-1110			
23	GASKET 1/2" ID, 1/2" TH	1	ASBESTOS	COMPL.	DPSC	904840-0001			
24									
25									
GAUGE ASSEMBLIES									
27	CENTERPLATE	1	BRASS	COMPL.	DPSC	102479-1112			
28	TUBE-BYPASS	1	BRASS	COMPL.	DPSC	102480-1114			
29	INSTRUCTION PLATE	1	BRASS	COMPL.	DPSC	100081-0110			
30	PIN-LATCH	2	BRASS	COMPL.	DPSC	102408-0117			
31	SHIM-RODSTEM	2	BRASS	COMPL.	DPSC	102477-1111			
32	END STEM UPPER	1	BRASS	COMPL.	DPSC	102474-1112			
33	END STEM LOWER	1	BRASS	COMPL.	DPSC	102474-1110			
34	FLANGE-GAUGE	2	BRASS	COMPL.	DPSC	102475-0117			
35	PIN-SCREEN GUIDE	2	BRASS	COMPL.	DPSC	102449-1114			
36	GASKET-SEALING	14	ASBESTOS	COMPL.	DPSC	102447-1112			
37	GASKET PROTECTIVE	14	ASBESTOS	COMPL.	DPSC	102446-1112			
38	GASKET NIPPLE	14	ASBESTOS	COMPL.	DPSC	102448-1110			
39	GLASS-GAUGE	14	GLASS	COMPL.	DPSC	102444-1111			
40	PACKING-STRIP	14	ASBESTOS	COMPL.	DPSC	102448-1112			
41	GASKET-ORIMON	14	ASBESTOS	COMPL.	DPSC	102448-1112			
42	COVER PLATE GAUGE	14	CARBON ST.	MIL-S-20000	DPSC	102449-1115			
43	CAP-BROW-SOCKET HD	28	CARBON ST.	MIL-S-20000	DPSC	102439-1112			
44	PLUG-SEAL	4	BRASS	COMPL.	DPSC	100181-0112			
45	FLY-SEAL	2	BRASS	COMPL.	DPSC	100181-0112			
46									
ILLUMINATOR ASSEMBLIES									
47	ILLUMINATOR ASSY	1	SEE ASSY	DPSC	102882-1028				
48									
49									
50									
WIDE ANGLE DIRECT READING HOOD ASSEMBLIES									
51	HOOD ASSY	1	SEE ASSY	DPSC	102426-1027				
52									
53									
54									
DRAIN VALVE ASSEMBLY (THE FOLLOWING DETAILS ARE									
55	DRAIN VALVE RUBBER	1	CARBON ST.	MIL-S-20000	DPSC	102281-0112			
56	1/8" O.D. DRAIN VALVE	2	BRASS	COMPL.	DPSC	3082-U			
57	NIPPLE-SHRODD	1	CARBON ST.	MIL-S-20000	DPSC	102393-0114			
58	1/8" HEX HD BOLT	2	STEEL	A191	DPSC	102428-1110			
59	1/8" HEX NUT	2	STEEL	A191	DPSC	102429-1110			
60	GASKET-ORIMON	1	ASBESTOS	COMPL.	DPSC	904840-0001			

LIST OF MATERIAL - QUANTITIES FOR ONE RH ASSY & ONE LH ASSY

PC NO	NAME	NO REQ OR 1 OR 2	MATERIAL	MATL SPEC	MANUFACTURERS NAME	DWG NO	BUSHIPS DWG NO	UNIT WT/LB	STD NAVY STOCK NO	REMARKS
UPPER VALVE ASSEMBLIES										
1	UPPER VALVE ASSY	1	SEE ASSY DWG 702333-2587	DRFC	DRFC	10246-4-007				
2	CONNECTOR BODY	1	CARBON STL	MIL-S-3015	DRFC	10247-0-016				
3	LOOP EXPANSION	1	CARBON STL	MIL-S-3015	DRFC	10247-0-012				
4	FLANGE LOOP	1	CARBON STL	MIL-S-3015	DRFC	10247-0-012				
5	ARM-GUIDE	1	CARBON STL	MIL-S-3015	DRFC	10238-0-013				
6	GUIDE EXPANSION	1	CARBON STL	MIL-S-3015	DRFC	10247-0-016				
7	1/2 HEX HD BOLT 3/4	4	CARBON STL	MIL-S-3015	DRFC	10272-1110				
8	1/2 HEX NUT	4	CARBON STL	MIL-S-3015	DRFC	10272-5110				
9	GASKET BODY 1/2" DIA	1	PRELUBRICATED ALUMINUM	COML	DRFC	90456-0002				6716 951
10										
11										
12										
LOWER VALVE ASSEMBLIES										
13	LOWER VALVE ASSY (SEE DETAIL)	1	SEE ASSY DWG 10246-4-007	DRFC	DRFC	10246-4-007				RIGHT HAND
14	LOWER VALVE ASSY (SEE DETAIL)	1	SEE ASSY DWG 10246-4-007	DRFC	DRFC	10246-4-007				LEFT HAND
15	NIPPLE DRAIN	1	CARBON STL	MIL-S-3015	DRFC	10237-0-016				
16	FLANGE DRAIN	1	CARBON STL	MIL-S-3015	DRFC	10237-0-017				
17	CONNECTOR BODY	1	CARBON STL	MIL-S-3015	DRFC	10247-0-016				
18	RESTRAINER-BALL	1	STAINLESS	ASTM A192	DRFC	10237-0-017				
19	GASKET 1/2" DIA	1	PRELUBRICATED ALUMINUM	COML	DRFC	90456-0001				114 930
20	1/2 DIA BALL CHECK	1	STAINLESS	ASTM A192	DRFC	10274-0-011				
21	1/2 HEX HD BOLT 3/4	4	CARBON STL	MIL-S-3015	DRFC	10272-1110				
22	1/2 HEX HD NUT	4	CARBON STL	MIL-S-3015	DRFC	10272-5110				
23	GASKET BODY 1/2" DIA	1	PRELUBRICATED ALUMINUM	COML	DRFC	90456-0002				6716 951
24										
25										
26										
GAUGE ASSEMBLIES										
27	CENTERPLATE	1	STAINLESS	ASTM A192	DRFC	10247-0-016				PC 27 SHOWN IN FIG 10247-0-016
28	TUBE BYPASS	1	STAINLESS	ASTM A192	DRFC	10248-0-016				
29	INSTRUCTION PLATE	1	BRASS	COML	DRFC	10248-0-010				
30	PIN LATCH	8	STAINLESS	ASTM A192	DRFC	10248-0-017				
31	SPRING ENDSTEM	4	STAINLESS	ASTM A192	DRFC	10247-0-011				
32	END STEM UPPER	1	STAINLESS	ASTM A192	DRFC	10247-0-011				
33	END STEM LOWER	1	STAINLESS	ASTM A192	DRFC	10247-0-011				
34	FLANGE GAUGE	2	CARBON STL	MIL-S-3015	DRFC	10237-0-017				
35	PIN SCREEN GUIDE	2	STAINLESS	ASTM A192	DRFC	10247-0-011				
36	GASKET SEALING	14	STAINLESS	ASTM A192	DRFC	10247-0-011				
37	GASKET PROTECTIVE	14	STAINLESS	ASTM A192	DRFC	10247-0-011				
38	GASKET MICA	14	MICA	INDIA MICA	DRFC	10247-0-011				FORMULA 400-2
39	GLASS GAUGE	14	GLASS	COML	DRFC	10244-1110				FORMULA 400-2
40	PACKING JUMP	14	ASBESTOS	COML	DRFC	10244-1112				STYLE A 3L
41	GASKET CUSHION	14	ASBESTOS	COML	DRFC	10244-1113				STYLE 60
42	COVER PLATE GAUGE	4	ASBESTOS	COML	DRFC	10244-1113				
43	CAP SCREEN SOCKET HD	8	CARBON STL	MIL-S-3015	DRFC	10247-0-011				
44	FLAP SEAL	4	STAINLESS	ASTM A192	DRFC	10015-0-012				
45	FLAP SEAL	2	CARBON STL	COML	DRFC	861801-0034				
46										
ILLUMINATOR ASSEMBLIES										
47	ILLUMINATOR ASSY	1	SEE ASSY DWG 10248-1048	DRFC	DRFC	10248-1048				PC 47 SHOWN IN FIG 10248-1048
48										
49										
50										
WIDE ANGLE DIRECT READING HOOD ASSEMBLIES										
51	HOOD ASSY	1	SEE ASSY DWG 10248-1048	DRFC	DRFC	10248-1048				PC 51 SHOWN IN FIG 10248-1048
52										
53										
54										
DRAIN VALVE ASSEMBLY (THE FOLLOWING DETAILS ARE SHIPPED LOOSE)										
55	DRAIN VALVE FLANGE	1	CARBON STL	MIL-S-3015	DRFC	10235-0-016				
56	1500 DRAIN VALVE	2	CARBON STL	MIL-S-3015	COML	3682-U				SEE DETAIL 3682-U
57	NIPPLE SCHEDULE 80	1	CARBON STL	MIL-S-3015	DRFC	10235-0-016				
58	10-10 AMER STD PIPE	8	CARBON STL	MIL-S-3015	DRFC	10272-4113				
59	STUD	4	ALLOY STL	MIL-S-3015	DRFC	10064-2110				
60	GASKET HOOD 1/2" DIA	1	PRELUBRICATED ALUMINUM	COML	DRFC	90455-0008				FLIGHTWALKER

NO	DESCRIPTION	DATE	BY	CHKD
A	CERTIFIED MIL-S-3015 CHANGES TO DETAIL 2 SHALL BE MADE TO THIS LIST. THESE CHANGES SHALL BE SHOWN WITH BUSHIPS DWG NO.	4/2/54	WJ	WJ
B	CERTIFIED MIL-S-3015 CHANGES TO DETAIL 2 SHALL BE MADE TO THIS LIST. THESE CHANGES SHALL BE SHOWN WITH BUSHIPS DWG NO.	4/2/54	WJ	WJ

NOTE A: THIS LIST IS USED FOR RECORD VISION. THE RED (MIL-S-3015) WATER MARK IS OBTAINED BY THE USE OF THE ILLUMINATOR PC 47 SHOWN IN FIG 10247-1110.

NOTE B: TO REMOVE GAUGE FROM VALVE WHILE THE GAUGE IS UNDER PRESSURE, CLOSE VALVE, ALIGN LOCK ARROWS ON GAUGE SYSTEM, POLE BARS AND REMOVE GAUGE TOWARD OPERATOR.

NOTE C: MILITARY WILL FURNISH MATERIAL OF COMMERICAL SPECIFICATIONS IN LIEU OF MILITARY SPECIFICATIONS FOR FILLS LISTED IN TABLE BELOW.

PC NO	MILITARY SPECIFICATION	COMMERCIAL SPECIFICATION
34	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
35	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
36	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
37	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
38	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
39	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
40	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
41	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
42	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
43	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
44	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
45	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA
46	MIL-S-3015 CL B	ASTM A192 C.P. 3015 STOKA

NO.	DESCRIPTION	QUANTITY	REMARKS
1	CENTERPLATE (CENTER PLATE)	1	
2	ILLUMINATOR (HOOD ASSY)	1	


ANY PURCHASES OF MIL-S-3015 SHALL BE MADE AT THE FOLLOWING:



23
20
19
ELEVATION
(SHOWN WITHOUT ILLUMINATOR & HOOD ASSEMBLY)

LIST OF MATERIAL QUANTITIES FOR



PC NO	NAME	NO REQD	MATERIAL	MAT'L SPEC	MANUFACTURER NAME	QUANTITY
(5) HOOD ASSEMBLY #1034826						
50	PLATE SIDE END	1	ALUMINUM	DPSC M1	DPSC	108490-180
51	PLATE SIDE END	1	ALUMINUM	DPSC M1	DPSC	03491-1139
52	PLATE END	2	ALUMINUM	DPSC M1	DPSC	103748-1114
53	STRIP SPACER	2	ALUMINUM	DPSC M1	DPSC	103771-1114
54	MARK	1	ALUMINUM	DPSC M1	DPSC	103773-1120
55	SCREW	8	STEEL	COM'L	METHEM	063681-0604
56	LENS	1	HYDALITE	COM'L	HOMALTA	103772-1113
57	WASHER	6	STEEL	COM'L	METHEM	063608-0810
58	WASHER NUT	6	STEEL	COM'L	METHEM	063687-0800
59	WASHER	6	STEEL	COM'L	METHEM	069010-0800
60	LAMP STEP	2	ALUMINUM	DPSC M1	DPSC	103774-1111
61	PLATE ADAPTOR	2	ALUMINUM	DPSC M1	DPSC	103670-1108
62						
63						
64						
65						
66						
67						
68						
69						



ENCLOSED (A) ADAPTER PLATE ASSEMBLY WAS ATTACHED TO (B) HOOD ASSEMBLY AS SHOWN.
ENCLOSED (C) ILLUMINATOR ASSEMBLY WAS TAPPED AND SLOTTED AS SHOWN.
THE ABOVE ASSEMBLYS WERE FURNISHED ON ORDER LW-12001 TEST GAUGES.

10 FT. OF CORD

NOTE:
LOCATE DET. 10 AWAY FROM ILLUMINATOR ASSEMBLY.



1




LIST OF MATERIAL QUANTITIES FOR ONE

PC NO	NAME	NO REQD	MATERIAL	MAT SPEC	MANUFACTURER NAME	MANUFACTURER PRT NO	DUSHPS DWG NO	NET WT LB	STD NAVY STOCK NO	REMARKS
(4) ILLUMINATOR ASBY. 103285-048 (SEE NOTE 1)										
1	BODY - ILLUMINATOR	1	ALUMINUM	DRSC	103483-039					SEE NOTE 1
2	LAMP HOUSING	1	ALUMINUM	DRSC	103287-019					SEE NOTE 1
3	RETAINER - COLOR SCREEN	1	ALUMINUM	DRSC	103288-018					SEE NOTE 1
4	SCREEN - COLOR RED	1	GLASS	COML	103289-018					FORMULA #440
5	SCREEN - COLOR GREEN	1	GLASS	COML	103290-018					FORMULA #440
6	RETAINER - LENS - BOTTOM	1	ALUMINUM	DRSC	103291-017					SEE NOTE 1
7	LENS - STRIP	1	GLASS	COML	103292-012					FORMULA #720
8	COVER ILLUMINATOR	2	ALUMINUM	DRSC	103483-111					SEE NOTE 1
9	COVER - TOP	1	ALUMINUM	DRSC	103483-012					SEE NOTE 1
10	BRACKET - SOCKET MOUNT	1	ALUM. BRK.	DRSC	103484-012					SEE NOTE 1
11	HOLDER - LAMP	7	BRASS	COML	103485-008					SEE NOTE 1
12	LAMP - 28 VOLT/40 WATT	7	GLASS	COML	103486-008					SEE NOTE 1
13	HINGE	1	STEEL	COML	103487-014					SEE NOTE 1
14	COBBIN CATCH STRIKE	10	STEEL	COML	103488-009					SEE NOTE 1
15	RETAINER - LENS	2	ALUMINUM	DRSC	103489-017					SEE NOTE 1
16	4x4 COARSE SCREW TYPE	4	STEEL	COML	103490-040					SEE NOTE 1
17	4x4 LOCKWASHER	4	STEEL	COML	103491-040					SEE NOTE 1
18	SPRING - STRIP LENS	4	BRASS	COML	103492-017					SEE NOTE 1
19	SPRING - STRIP	1	BRASS	COML	103493-017					SEE NOTE 1
20	3/16" HD. FLK. SCREW	40	STEEL	COML	103494-040					CAD PLATED
21	1/8" HD. FLK. SCREW	40	STEEL	COML	103495-040					CAD PLATED
22										
23	10-32 X 1/2" HD. FLK. SCREW	4	STEEL	COML	103496-040					CAD PLATED
24	1/8" HD. FLK. SCREW	8	STEEL	COML	103497-040					CAD PLATED
25	1/4" X 1/2" X 1/8" PLATE	16	STEEL	COML	103498-040					CAD PLATED
26	1/4" X 1/2" X 1/8" PLATE	16	STEEL	COML	103499-040					CAD PLATED
27	COVER - BOTTOM (MOUNTING)	1	ALUMINUM	DRSC	103500-012					SEE NOTE 1
28	LENS - STRIP	1	GLASS	COML	103501-012					FORMULA #720
29	TRANSFORMER - 250 WATT	1	ALUMINUM	DRSC	103502-012					SEE NOTE 1
30	RETAINER - LENS - TOP	2	ALUMINUM	DRSC	103503-017					SEE NOTE 1
31	STRIP - 1/4" X 1/2" X 1/8"	4	STEEL	COML	103504-040					CAD PLATED
32										
33	BASKET	1	BRASS	COML	103505-017					SEE NOTE 1
34	SCREEN - COLOR RED 1/4" LG	1	GLASS	COML	103506-012					FORMULA #440
35	SCREEN - COLOR GREEN 1/4" LG	1	GLASS	COML	103507-012					FORMULA #440
36	CLIP - COLOR SCREEN	4	BRASS	COML	103508-012					SEE NOTE 1
37	ROLL PIN	4	STEEL	COML	103509-012					SEE NOTE 1
38	COPPER WIRE #14 24 LG	1	COPPER	COML	103510-012					SEE NOTE 1
39	COPPER WIRE #14 24 LG	1	COPPER	COML	103511-012					SEE NOTE 1
40	TUBING 1/2" X 1/4" LG	2	STEEL	COML	103512-012					SEE NOTE 1
41	TUBING 1/2" X 2 1/2" LG	2	STEEL	COML	103513-012					SEE NOTE 1
42										
43	WIRE - LAMP	10	STEEL	COML	103514-012					SEE NOTE 1
44	CONNECTOR - PLUG	1	BRASS	COML	103515-012					SEE NOTE 1
45	CONNECTOR - RECP.	1	BRASS	COML	103516-012					SEE NOTE 1
46										
47										
48										
49										

REV	DESCRIPTION	DATE	BY
A	CERTIFIED WPS'S CHANGES. ADDED WIDE ANGLE VISION HOOD ASSEMBLY. ILLUMINATOR ASSEMBLY WAS SHOWN WITH SLANTED HOLES AS SHOWN IN THE ENCLOSED VIEW OF THE 21 TEST CHANGE SHEET ASBY'S TO CALL FOR STANDARD HOLES.	10/26/50	W.C.

NOTE: HOOD ASSEMBLY IS P.C. 11 ON 103486-1087

NOTE: ILLUMINATOR ASSEMBLY IS P.C. 17 ON 103486-1087



(5) HOOD ASBY. 103486-1087

SECTION X-X


PAINT SPEC. PAINT INSIDE HOODS WITH F. 24 DULL BLACK

DRAWN BY CHECKED BY DATE 6-2-51	MASTER DRAWING ILLUMINATOR WIDE ANGLE HOOD ASBY. FOR DP-5000 (SURA-PORT) SC. NAVY TYPE GAUGE.	DWS. NO. 103486-1087 NAVY DEPT. ENGINEERING
PLATE 2		

3



DIAMOND DURA-PORT WATER GAGE
MAIN BODY



DIAMOND DURA-PORT WATER GAGE WITH VIEWING
HOOD AND ILLUMINATOR ATTACHED

COPY

U. S. NAVAL RESEARCH LABORATORY
WASHINGTON 25, D. C.

In Reply Refer To.
6253-49A:RCN:dd
NRL Prob F03-15
12 September 1962

Shock and Vibration Folder No. 920

Subj: Dura-Port Boiler Water-Level Gage, vibration and shock testing of; NRL Problem F03-15; report on

Ref: (a) NBTL ltr Code 2722-9510(B-490) (B-518) (B-526) of 2 Feb 1962
(b) Mil Spec MIL-STD-167 of 20 Dec 1954 for vibration
(c) Mil Spec MIL-S-901B(Navy) of 9 Apr 1954 for shock

Fig: (1) Gage assembly, prior to modifications, mounted on the table of a reaction type vibration machine. (The boiler drum nozzles are shown in an intermediate stage of development.)
(2) Gage assembly on vibration machine following modifications and development of boiler drum nozzles.
(3) Sketch of suitable boiler drum nozzles to which gage assembly was secured.
(4) Close-up showing modified upper suspension system for gage.
(5) Gage assembly mounted on vibration machine table for testing in horizontal direction perpendicular to the front.
(6) Gage assembly secured to a 30-degree inclined bulkhead fixture and mounted on the table of a medium-weight high-impact shock machine.

Introduction

1. As requested in reference (a) vibration and shock tests in accordance with references (b) and (c) respectively were conducted on a DP-3000 Dura-Port Boiler Water Level Gauge manufactured by Diamond Power Specialty Corporation of Lancaster, Ohio. This report concludes the vibration and shock work on this phase of the problem.

Encl (1) to NRL ltr
6253-49:RCN:dd
SER: 9818

APPENDIX I

2. The tests were conducted at the U. S. Naval Research Laboratory Washington 25, D. C. during the period 26 February through 16 April 1962 and were witnessed by representatives of the manufacturer, Naval Boiler and Tubbine Laboratory, and BUSHIPS.

Description of Unit

3. The gage assembly without the illuminator and wide-angle viewer weighed 175 lb. Its maximum dimensions were: Height 50-1/2 in.; Width 29 in.; Depth 12 in. The aluminum illuminator and steel wide-angle viewer totaled 33 lb. The illuminator was equipped with seven (7) 28-volt, 40 watt reflector type lamps manufactured by Grimes Mfg. Co. of Urbana, Ohio (Grimes part No. 10022). The gage was hydrostatically pressurized to 1500 psig during the variable frequency, and 2-hr endurance vibration tests, and the shock tests.

Vibration Testing Procedure

4. The unit was tested on a reaction-type vibration machine and was subjected to the outlined test procedure separately in each of the 3 mutually perpendicular directions. The test procedure in accordance with reference (b) was as follows:

a. Exploratory Vibration Test. With a table excursion of 0.020 in., an exploratory vibration check was conducted between 5 and 33 cps in discrete frequency intervals of 1 cps at 15 sec per interval.

b. Variable Frequency Test. Vibration was conducted between 5 and 33 cps in discrete frequency intervals of 1 cps at 5 min per interval. The frequency and corresponding table vibratory excursions were as follows: 5-15 cps, 0.060 in.; 16-25 cps, 0.040 in.; and 26-33 cps, 0.020 in.

c. Endurance Test. A 2-hr test in each direction was required at 33 cps or at any resonant frequency below 33 cps, at the appropriate table vibratory excursion outlined in paragraph 4b.

Exploratory Vibration - Horizontal Direction Parallel with the
Front Boiler-Drum Nozzle Development

5. The gage assembly was secured at its mounting flanges to the flanges of a pair of boiler drum nozzles supplied by NBT. The 1-5/8-in OD x 13/16-in ID steel nozzles were welded to a steel plate which simulated a boiler drum and was secured to a mounting bulkhead on the table of a reaction type vibration machine (Figure 1). With no reinforcing gussets welded to the nozzles the mounted assembly resonated at 14 cps with a TR of 33.5:1 (Transmissibility Ratio is the ratio of the unit's excursion to the vibration table excursion) measured at the gage body. In several stages of development maximum rigidity and the best vibration characteristics of the nozzles were achieved with 4 gussets welded to the nozzles and flanges and steel mounting plate as shown in Figure 2 and delineated in Figure 3. With this arrangement resonance of the gage assembly was observed at 27 cps with a TR of approximately 10:1 measured on the gage.

Development of Gage-Assembly Suspension

6. During the exploratory vibration test the following developmental corrections and modifications were incorporated in the gage assembly to improve its structural and vibration characteristics:

a) Relative motion between the gage upper and lower valve mounting flanges and the nozzle mounting flanges was eliminated by inserting a ring-type steel spacer between the 2 flanges (Figure 4).

b) The single-pipe expansion-loop suspension at the upper end of the gage was replaced with a more rigid double-pipe expansion, loop suspension (Figure 4).

c) Side-to-side relative motion between the upper valve assembly and the upper end of the gage assembly was reduced by a key and keyway block assembly (Figure 4). Clearance between mating parts must be provided at the upper suspension area to allow for thermal expansion.

d) The suitcase-type latches did not adequately secure the illuminator and wide-angle viewer which were suspended each on four 1/4-in diam. steel pins projecting from the gage. The latches

were removed. The 1/4-in diam. steel pins were each replaced with a 5/16-18NC hex-socket-head cap screw which secured the illuminator and viewer to the gage (Compare Figures 1 and 2).

e) Cracks developed in the viewer around its suspension slots and at the sharp 90-degree bend where it fitted around the gage. The portion of the viewer which was fitted and secured to the gage was reinforced by tack and spot welding a 7/64-in thick formed steel plate to the full length of each side (Figures 4 and 5).

The foregoing corrections and modifications raised resonance above 33 cps and lowered the TR to approximately 6:1 measured at the upper end of the gage body when vibrated in the horizontal direction parallel with the front.

Variable Frequency and Two-Hr Endurance Tests - Horizontal Direction Parallel with the Front

8. The variable frequency test from 5 through 33 cps, and the 2-hr endurance test at 33 cps in accordance with paragraphs 4b and 4c respectively were completed satisfactorily.

Vibration Testing - Vertical Direction

9. No resonances were observed below 33 cps in this direction and the maximum TR of 4.3:1 was measured at the upper end of the gage body at this frequency.

10. The variable frequency test from 5 through 33 cps, and the 2-hr endurance test at 33 cps were conducted without damage or hydraulic leaks.

Vibration Testing - Horizontal Direction Perpendicular to the Front

11. The gage assembly was mounted on the vibration machine table as shown in Figure 5 for testing in this direction. No resonances were observed below 33 cps and the maximum TR of approximately 2:1 was measured at the upper end of the gage.

12. The variable frequency test, 5-33 cps, and the 2-hr endurance test at 33 cps were conducted satisfactorily.

Shock Testing Procedure

13. The gage and nozzle assembly mounting plate was secured to a 30-degree inclined-bulkhead fixture which was mounted on the table of a mediumweight high-impact shock machine (Figure 6). The gage was pressurized to 1500 psig. during the shock testing procedure.

14. With a total of 2925 lb. on the shock machine table the assembly was subjected to a total of 6 Class A shock blows in accordance with reference (c). The shock blows consisted of 2 hammer drops from a height of 1.25 ft with a 3-in table travel, 2 drops from a height of 2.25-ft with a 3-in table travel, and 2 drops from a height of 2.25 ft with a 1-1/2-in table travel. The lamp positions in the illuminator were designated numerically with No. 1 at the top.

15. The results of the shock blows were:

a. Blow 1. 1.25 ft hammer drop, 3-in table travel.

1. The filaments of bulbs Nos. 1, 3, 6, and 7 fractured. New bulbs were inserted. No other damage resulted.

b. Blow 2. 1.25-ft hammer drop, 3-in table travel.

1. The filaments of bulbs Nos. 2, 6, and 7 fractured. The bulbs were replaced.

c. Blow 3. 2.25 ft hammer drop, 3-in table travel.

1. The filaments of bulbs Nos. 1, 3, and 6 fractured. No replacements were made.

2. A 0.070 in. vertical clearance was measured between the keyblock and keyway block.

d. Blow 4. 2.25-ft hammer drop, 3-in table travel.

1. The filaments of bulbs Nos. 4 and 7 failed. The bulbs were not replaced.

2. A clearance of 0.115 in. was measured between the keyblock and the keywayblock.

e. Blow 5. 2.25 ft hammer drop, 1-1/2-in table travel.

1. The filament of bulb No. 5 failed. The bulb was not replaced.

2. A 7/32-in clearance was measured between the keyblock and keywayblock.

f. Blow 6. 2.25-ft hammer drop, 1-1/2-in table travel.

1. No additional obvious damages resulted from this blow.

16. Following completion of shock testing examination of the interior of the viewer showed the lower strip lens to be fractured at the retaining spring, and the upper strip lens was chipped at its lower support bracket. The progressive increase of clearance between the keyblock and keywayblock resulted from slight deformation of the double-pipe expansion assembly. The use of a dovetail-shaped key and keyway would prevent separation of mating parts. No hydrostatic pressure drop resulted in the gage from the 6 shock blows. Following shock testing the gage was pressurized hydrostatically to 2250 psig for 30 min and no leaks were observed.

Conclusions

17. On the basis of the tests conducted the subject gage is considered satisfactory for vibration and shock conditions as defined by references (b) and (c) respectively subject to compliance with the following recommendations.

Recommendations

18. It is recommended that:

a. The gage assembly shall be secured to boiler drum nozzles which are at least as rigid as the modified nozzles developed at NRL and shown in Figures 2 and 3.

6253-49A:RCN:dd
NRL Prob F03-15

b. The modifications and corrections noted in paragraphs 6a through 6e or their equivalent be incorporated in the production model gage assembly.

c. If available, the use of Navy "rough-service" type lamps in the illuminator should be considered.

Report prepared by

Report approved by

/s/ Richard C. Nowak
Richard C. Nowak
Mechanical Engineer


/s/ Harold M. Forkois
Harold M. Forkois
Mechanical Engineer



6253-49A

1246-12-02(1)

Figure 1




BOILER GAUGE NOZZLE REINFORCEMENT

6253-49A

60-1-63

Figure 3



STEEL SPACER

KEY BLOCK


KEYWAY BLOCK

DOUBLE PIPE LOOP SUSPENSION

6253-19A

100-1-10 ()


Figure 1



STEEL PLATE

6253-19A

Figure 5



62-11-10A

Figure 6

The gage was shock and vibration tested at NRL. The gage insert withstood shock and vibration tests without leakage or glass failure; the illuminator and hood assembly required modification to provide adequate shock and vibration resistance. Readability of the gage, requiring reliance on the color-refraction principle, was considered satisfactory while incorporating a better than 100° viewing angle. Optimum discernment of water level was obtained at

(See other card)

The gage was shock and vibration tested at NRL. The gage insert withstood shock and vibration tests without leakage or glass failure; the illuminator and hood assembly required modification to provide adequate shock and vibration resistance. Readability of the gage, requiring reliance on the color-refraction principle, was considered satisfactory while incorporating a better than 100° viewing angle. Optimum discernment of water level was obtained at

(See other card)

The gage was shock and vibration tested at NRL. The gage insert withstood shock and vibration tests without leakage or glass failure; the illuminator and hood assembly required modification to provide adequate shock and vibration resistance. Readability of the gage, requiring reliance on the color-refraction principle, was considered satisfactory while incorporating a better than 100° viewing angle. Optimum discernment of water level was obtained at

(see other card)

The gage was shock and vibration tested at NRL. The gage insert withstood shock and vibration tests without leakage or glass failure; the illuminator and hood assembly required modification to provide adequate shock and vibration resistance. Readability of the gage, requiring reliance on the color-refraction principle, was considered satisfactory while incorporating a better than 100° viewing angle. Optimum discernment of water level was obtained at

(See other card)