

AD-A110 233


NAVAL FACILITIES ENGINEERING COMMAND ALEXANDRIA VA
STRUCTURAL ENGINEERING. CONCRETE STRUCTURES. DESIGN MANUAL 2.4.(U)
MAY 80

F/6 13/13


UNCLASSIFIED

ML

1 of 1
AD-A110 233



END
DATE
FILMED
2-82
DTIC




MICROCOPY RESOLUTION TEST CHART

NATIONAL BUREAU OF STANDARDS

LEVEL

NAVFAC DM-24
MAY 1980



AD A110233

STRUCTURAL ENGINEERING

DTIC
ELECTE
FEB 1 1982
S **D**
H

CONCRETE STRUCTURES

DESIGN MANUAL 2.4

APPROVED FOR PUBLIC RELEASE

DTIC FILE COPY

DEPARTMENT OF THE NAVY
NAVAL FACILITIES ENGINEERING COMMAND

200 STOVALL STREET
ALEXANDRIA, VA. 22332

DISTRIBUTION: (1 copy each unless otherwise specified)

SNDL		FF6		FR3
23A1	(COMNAVFORAZORES only)	FF19	(Brooklyn, New Orleans, and Seattle only)	FR4
24J1				FT1
27G		FF38		FT2
39B		FG2	(Balboa, Harold Holt, Nea Makri, Thurso, Stockton, and Ponce only)	FT6
39C1				FT13
39E				FT18
42A3		FG3	(Cheltenham and East Machias only)	FT19
45B				FT22
49		FG6	(Wahiawa and Norfolk only)	FT27
51A		FH3	(Beaufort only)	FT28
51B1		FH6	(Bethesda only)	FT31
51B3		FH8	(Cairo only)	FT37
B1	(SECDEF only)	FH25	(Philadelphia, Portsmouth VA, Camp Lejeune, Oakland, Newport, Great Lakes, and Long Beach only)	FT55
B2A	(JCS, NSA, DLA, and DNA only)			FT64
B5	(USCG only)			FT73
C34	(Holy Loch, Souda Bay only)	FJ5		FT74A
		FKA6A1		FT74B
C37D	(Port Hueneme only)	FKA6A2		
E3A	(Washington, Barrow, Oakland only)	FKA6A3A		FT78
FA6	(Bermuda, Brunswick, Cecil Field, Key West, Jacksonville, Virginia Beach only)	FKA6A3B		V2
FA7	(Guantanamo, Keflavik, Panama Canal, Mayport, Roosevelt Roads only)	FKA6A9		V3
		FKA6A12		V5
FA10		FKA6A15	(Code LA 151)	V8
FA18		FKA6A16		V12
FA23	(Antigua, Brawdy, Buxton, Lewes only)	FKA9		V14
FA25	(10 copies)	FKM8		V15
FA32		FKM9		V16
FB6		FKM12		V17
FB7	(Alameda, Fallon, Lemoore, Oak Harbor, Miramar, North Island, Moffet Field only)	FKM13		V23
		FKM15	(Philadelphia only)	
FB10		FKN1	(West and Lant only (85 copies each))	Copy to: (one copy each unless otherwise indicated)
FB21		FKN1	(South and North only (50 copies each))	
FB31	(Guam only)	FKN1	(Pac and Ches only (25 copies each))	21A
FB33		FKN1	(Ches, FPO-1 only)	A2A
FB34	(Kadena only)	FKN2		(ONR only)
FB36	(Big Sur, Coos Head, Ferndale, and Pacific Beach only)	FKN3	(6 copies each)	A3
		FKN5		A4A
FB41		FKN8		A5
FB48		FKN10	(less Concord)	A6
FC3	(London only)	FKP1B	(Concord only - 3 copies)	(Code LFF)
FC4	(Sigonella only)	FKP1E		C7
FC5		FKP1J		(Brazil and Chile only)
FC7		FKP1M		FD1
FC12		FKP3A		FE1
FD2		FKP7		FG1
FE2		FKP8		FKA1A
FE4	(Adak, Edzell, Hanza, Galeta Island, Homestead, Winter Harbor, Sabana Seca, and Sonoma only)	FKP11		FKA1B
		FKQ3		(2 copies)
FF1	(Washington only)	FKR1A		FKA1C
FF5		FKR1B	(2 copies)	(Code 043 - 50 copies)
		FKR2A	(Dallas only)	FKA1F
		FKR3A		FKN2
		FKR3C		(Port Hueneme (Code 156) only)
		FKR3H		FR1
		FKR4B		
		FKR5		Additional copies are available from:
		FKR7E	(3 copies)	Commanding Officer
				Naval Publications and
				Forms Center
				5801 Tabor Avenue
				Philadelphia, PA 19120

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER NAVFAC DM-2.4	2. GOVT ACCESSION NO. AD-A110 233	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) NAVFAC Design Manual DM-2.4 Structural Engineering Concrete Structures		5. TYPE OF REPORT & PERIOD COVERED Design Criteria Final
7. AUTHOR(s) Naval Facilities Engineering Command 200 Stovall Street Alexandria, VA 22332 (Code 0452)		6. PERFORMING ORG. REPORT NUMBER DM-2.4
9. PERFORMING ORGANIZATION NAME AND ADDRESS Naval Facilities Engineering Command 200 Stovall Street Alexandria, VA 22332		8. CONTRACT OR GRANT NUMBER(s)
11. CONTROLLING OFFICE NAME AND ADDRESS Naval Facilities Engineering Command (Code: 0432) 200 Stovall Street Alexandria, VA 22332		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS Engineering and Design
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		12. REPORT DATE May 1980
		13. NUMBER OF PAGES 26
		15. SECURITY CLASS. (of this report) Unclassified
16. DISTRIBUTION STATEMENT (of this Report) Unclassified/Unlimited		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report) Unclassified/Unlimited		
18. SUPPLEMENTARY NOTES		
		82 01 29 050
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Aggregate concrete; Class A, B, and C Structures; concrete strength; joints; limited life structures; plain concrete; reinforced concrete.		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) Basic criteria for the design of concrete structures, except floating structures and pavements, are presented for use by experienced engineers and architects. Design standards are established for Class A (Bridge), Class B (Building), and Class C (Special) structures. A discussion of special considerations such as concrete protection, types of aggregate joints, climatic influences, shear effects, design criteria for slabs-on-grade, and capacities of anchor bolts is included.		

ABSTRACT

Basic criteria for the design of concrete structures, except floating structures and pavements, are presented for use by experienced engineers and architects. Design standards are established for Class A (Bridge), Class B (Building), and Class C (Special) structures. A discussion of special considerations such as concrete protection, types of aggregate joints, climatic influences, shear effects, design criteria for slabs-on-grade, and capacities of anchor bolts is included.

Accession For	
NTIS Grant	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By _____	
Distribution/	
Availability Codes	
Avail and/or	
Dist	Special
A	

DTIC
COPY
INSPECTED
1

2.4-111

FOREWORD

This design manual is one of a series developed from an evaluation of facilities in the shore establishment, from surveys of the availability of new materials and construction methods, and from selection of the best design practices of the Naval Facilities Engineering Command, other Government agencies, and the private sector. This manual uses to the maximum extent feasible, national professional society, association, and institute standards in accordance with NAVFACENGCOM policy. Deviations from these criteria should not be made without prior approval of NAVFACENGCOM Headquarters (Code 04).

Design cannot remain static any more than can the naval functions it serves or the technologies it uses. Accordingly, recommendations for improvement are encouraged from within the Navy and from the private sector and should be furnished to NAVFACENGCOM Headquarters, Code 04. As the design manuals are revised, they are being restructured. A chapter or a combination of chapters will be issued as a separate design manual for ready reference to specific criteria.

This publication is certified as an official publication of the Naval Facilities Engineering Command and has been reviewed and approved in accordance with SECNAVINST 5600.16.



D. G. Iselin
Rear Admiral, CEC, U.S. Navy
Commander
Naval Facilities Engineering Command

STRUCTURAL ENGINEERING DESIGN MANUALS

<u>New DM Number</u>	<u>Superseded Chapter in Basic DM</u>	<u>Subject</u>
2.1	-	General Requirements
2.2	1	Loads
2.3	2	Steel Structures
2.4	3	Concrete Structures
2.5	4	Timber Structures
2.6	5, 6, 7, 8	Aluminum Structures Masonry Structures Composite Structures Other Structural Materials
2.7	-	Snow Loads (Tri-Service)

CONTENTS
CONCRETE STRUCTURES

	<u>Page</u>
Section 1. SCOPE AND RELATED CRITERIA	2.4-1
1. SCOPE	2.4-1
2. CANCELLATIONS	2.4-1
3. RELATED CRITERIA	2.4-1
4. CONCRETE STRENGTH	2.4-1
5. STANDARD SPECIFICATIONS	2.4-3
Section 2. DESIGN STANDARDS	2.4-3
Part 1. CLASS A STRUCTURES	2.4-3
1. HIGHWAY BRIDGES	2.4-3
2. RAILROAD BRIDGES	2.4-3
3. OTHER	2.4-3
Part 2. CLASS B STRUCTURES	2.4-4
1. REINFORCED CONCRETE	2.4-4
2. PLAIN CONCRETE	2.4-4
3. MODIFICATIONS	2.4-4
a. Concrete Cover for Severe Exposure Conditions	2.4-4
b. Concrete Footings Bearing on Rock or Other Hard Material	2.4-4
Part 3. CLASS C STRUCTURES	2.4-4
1. GENERAL	2.4-4
2. CHIMNEYS	2.4-4
3. BINS, SILOS, AND BUNKERS	2.4-4
4. TANKS AND RESERVOIRS	2.4-4
a. Non-Prestressed Tanks	2.4-4
b. Prestressed Tanks	2.4-4
c. Cover	2.4-4
d. Underground Tanks	2.4-4
e. Tanks for Storage of Liquids Other Than Water	2.4-5
f. Foundations	2.4-5
g. Temperature Gradient	2.4-5
Section 3. SPECIAL CONSIDERATIONS	2.4-5
1. CONCRETE PROTECTION FOR REINFORCEMENT	2.4-5
a. Normal Exposure Conditions	2.4-5
b. Seawater Exposure	2.4-5
c. Tanks and Reservoirs	2.4-5
d. Severe Exposure Conditions	2.4-5

CONTENTS (continued)

	<u>Page</u>
2. LIGHTWEIGHT AGGREGATE CONCRETE	2.4-6
a. Design Standard	2.4-6
b. Acceptable Types of Aggregate	2.4-6
c. Questionable Types of Aggregate	2.4-6
d. Usage	2.4-6
e. Unit Weights	2.4-6
f. Shrinkage and Creep	2.4-6
3. HEAVYWEIGHT AGGREGATE CONCRETE	2.4-6
a. Basis of Design	2.4-6
b. Acceptable Aggregates	2.4-8
c. Questionable Types of Aggregate	2.4-8
4. CORAL-AGGREGATE CONCRETE	2.4-8
a. Basis of Design	2.4-8
b. Application	2.4-8
c. Cover Over Reinforcement	2.4-8
5. JOINTS	2.4-8
a. Expansion Joints	2.4-8
b. Control Joints	2.4-9
c. Sealing Joints	2.4-9
6. CLIMATIC INFLUENCES	2.4-9
a. Cold Regions	2.4-9
b. Tropical Regions	2.4-9
c. Salt (Chlorides) in Mixing Water in Aggregates	2.4-9
7. SHEAR TRANSFER	2.4-10
a. Compatibility	2.4-10
b. Shear on Keys	2.4-10
8. SLABS-ON-GRADE	2.4-10
a. Design Conditions	2.4-10
b. Bending Stresses	2.4-10
c. Subgrade Drag	2.4-10
d. Joints	2.4-13
9. ANCHOR BOLTS	2.4-13
10. LIMITED LIFE STRUCTURES	2.4-13
a. Application	2.4-13
b. Modifications of Concrete Mix	2.4-15
c. Reduction of Cover	2.4-15
METRIC CONVERSION FACTORS	2.4-16
REFERENCES	Reference-1

CONTENTS (continued)

FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1.	Shrinkage and Creep Data for Lightweight Concrete	2.4-7
2.	Average Relationship Between Compressive Strength of 6 x 12-inch Cylinders and Flexural Strength of Beams Tested by Third-Point Loadings	2.4-11
3.	Design Aid for Slabs-On-Grade	2.4-12

TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
1.	Recommended Concrete Strengths	2.4-2
2.	Soil Classifications	2.4-14
3.	Allowable Shear and Tension on Bolts	2.4-14

Section 1. SCOPE AND RELATED CRITERIA

1. SCOPE. This manual prescribes criteria for the design of concrete structures, except floating structures and pavements.
2. CANCELLATIONS. This manual, NAVFAC DM-2.4, Concrete Structures, cancels and supersedes Chapter 3 of Structural Engineering, NAVFAC DM-2, of October 1970, and Changes 1 and 2.
3. RELATED CRITERIA. Certain criteria related to the design of concrete structures appear in other manuals in the design manual series and in other sources, as follows:

<u>Subject</u>	<u>Source</u>
General Requirements Service Classification	NAVFAC DM-2.1
Soil Mechanics, Foundations, Earth Structures Foundations	NAVFAC DM-7
Fire Protection Engineering Fire Protection	NAVFAC DM-8
Cold Regions Engineering Concrete in Cold Regions	NAVFAC DM-9
Liquid Fueling and Dispensing Facilities . . Underground Concrete Storage Tanks	NAVFAC DM-22
Bridges	Standard Specifica- tion for Highway Bridges, AASHTO Standard Manual for Railway Engineering, AREA Standard.
Building Code Requirements for Reinforced Concrete Reinforced Concrete	ACI Standard 318
Plain Concrete	ACI Standard 322
Chimneys	ACI Standard 307
General Criteria for Waterfront Construction Exposure to Seawater	NAVFAC DM-25.7

4. CONCRETE STRENGTH. Recommended concrete strengths for various types of structures and various exposures are listed in Table 1.

TABLE 1
Recommended Concrete Strengths

Application	Recommended Strength*
1. Mass concrete, not exposed to atmospheric conditions or other deteriorating agents, where mass rather than strength is principal condition.	2000 psi (13.79 MPa),** or less
2. Fills.	"
3. Encasements for utility lines and ducts.	2500 psi (17.24 MPa)
4. Concrete exposed to frost action where 2000 psi concrete would otherwise be used.	"
5. Foundation walls and footings.	3000 psi (20.68 MPa)
6. Drainage and utility structures.	"
7. Mass concrete exposed to sea water or other deteriorating agents.	"
8. Cast-in-place concrete piles for shore use.	"
9. Retaining walls subject to ordinary exposure conditions.	"
10. Reinforced concrete buildings and similar structures.	3000 to 3500 psi (20.68 to 24.13 MPa)
11. Architectural precast members.	3000 to 4000 psi (20.68 to 27.58 MPa)
12. Structures to contain noncorrosive fluids such as tanks and reservoirs.	3500 to 4000 psi (24.13 to 27.58 MPa)
13. Waterfront structures on fresh water.	3500 (24.13 MPa)
14. Reinforced concrete structures over sea water which are sufficiently elevated so that they are not ordinarily wetted by salt water.	"
15. Walls subjected to severe exposure conditions.	3500 to 4000 psi (24.13 to 27.58 MPa)
16. Concrete deposited under water (tremie concrete).	"
17. Mass concrete exposed to sea water from 3 ft below low water to 3 ft above high water or above normal action.	3500 psi (24.13 MPa)
18. Columns in multistory buildings carrying heavy loads.	4000 psi (27.58 MPa)