

**DOD COALESCER QUALIFICATION TO
MIL-F-52308J AMENDMENT 2**

**INTERIM REPORT
TFLRF No. 398**

by
Gary B. Bessee

**U.S. Army TARDEC Fuels and Lubricants Research Facility
Southwest Research Institute[®] (SwRI[®])
San Antonio, TX**

for
**U.S. Army TARDEC
Force Projection Technologies
Warren, Michigan**

Contract No. DAAE-07-99-C-L053 (WD48)

Approved for public release: distribution unlimited

June 2009

Disclaimers

The findings in this report are not to be construed as an official Department of the Army position unless so designated by other authorized documents.

Trade names cited in this report do not constitute an official endorsement or approval of the use of such commercial hardware or software.

DTIC Availability Notice

Qualified requestors may obtain copies of this report from the Defense Technical Information Center, Attn: DTIC-OCC, 8725 John J. Kingman Road, Suite 0944, Fort Belvoir, Virginia 22060-6218.

Disposition Instructions

Destroy this report when no longer needed. Do not return it to the originator.

DOD COALESCER QUALIFICATION TO MIL-F-52308J AMENDMENT 2

**INTERIM REPORT
TFLRF No. 398**

by
Gary B. Bessee

**U.S. Army TARDEC Fuels and Lubricants Research Facility
Southwest Research Institute[®] (SwRI[®])
San Antonio, TX**


for
**U.S. Army TARDEC
Force Projection Technologies
Warren, Michigan**

**Contract No. DAAE-07-99-C-L053 (WD48)
SwRI[®] Project No. 08.03227.48**

Approved for public release: distribution unlimited

June 2009

Approved by:



**Steven D. Marty, P.E. Director
U.S. Army TARDEC Fuels and Lubricants
Research Facility (SwRI[®])**

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing this collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports (0704-0188), 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number. **PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ADDRESS.**

1. REPORT DATE (<i>DD-MM-YYYY</i>) 31-12-2008		2. REPORT TYPE Final Interim Report		3. DATES COVERED (<i>From - To</i>) May 2008 – December 2008	
4. TITLE AND SUBTITLE DoD Coalescer Qualification to MIL-F-52308J Amendment 2				5a. CONTRACT NUMBER DAAE07-99-C-L053	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S) Bessee, G.B.				5d. PROJECT NUMBER SwRI 08.03227.48	
				5e. TASK NUMBER WD 48	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) U.S. Army TARDEC Fuels and Lubricants Research Facility (SwRI®) Southwest Research Institute® P.O. Drawer 28510 San Antonio, TX 78228-0510				8. PERFORMING ORGANIZATION REPORT NUMBER TFLRF No. 398	
9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES) U.S. Army RDECOM U.S. Army TARDEC Force Projection Technologies Warren, MI 48397-5000				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION / AVAILABILITY STATEMENT Approved for public release; distribution unlimited					
13. SUPPLEMENTARY NOTES					
14. ABSTRACT Aviation fuel filters are required for field operations and need to be qualified per military specifications. Currently, one supplier is qualified to provide aviation fuel filters meeting MIL-PRF-52308J Amendment 2. TARDEC would like to determine if other manufacturers have product that will also pass this test protocol. Four other manufacturers were recommended by TARDEC to obtain elements from and to evaluate per MIL-PRF-52308J Amendment 2. The objective of this project is to qualify additional suppliers coalescers to MIL-F-52308J Amendment 2 at the Army approved aviation filter test facility at Southwest Research Institute (SwRI), San Antonio, TX. Velcon had previously qualified a product meeting MIL-PRF-52308J Amendment 2. Products from additional manufacturers were evaluated to provide TARDEC with multiple vendors. The Kaydon elements did not pass the structural nor single element tests (SET). The PecoFacet elements failed both the single element (SET) and full-scale tests at the 3% water challenge. The Velcon elements pass all tests except the 3% water challenge during the full-scale test. The Parker Hannifin – Racor elements passed all of the tests and meet the requirements of MIL-PRF-52308J Amendment 2.					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT	18. NUMBER OF PAGES	19a. NAME OF RESPONSIBLE PERSON
a. REPORT Unclassified	b. ABSTRACT Unclassified	c. THIS PAGE Unclassified	Unclassified	32	19b. TELEPHONE NUMBER (<i>include area code</i>)

Standard Form 298 (Rev. 8-98)
Prescribed by ANSI Std. Z39.18

EXECUTIVE SUMMARY

Problems: The military has only one qualified producer of DoD aviation fuel filters

Objective: Provide the military with additional qualified aviation fuel filter supplier.

Importance of Project: Provide the military with elements in the field to properly filter aviation fuel.

Technical Approach: The technical approach was to utilize the currently approved test protocol to qualify product for the field.

Accomplishments: The test articles were evaluated and produced an additional supplier meeting MIL-PRF-52308J Amendment 2.

Military Impact: This program provided TARDEC with an additional supplier for aviation fuel filters meeting MIL-PRF-52308J Amendment 2 qualifications.

FOREWORD/ACKNOWLEDGMENTS

The U.S. Army TARDEC Fuel and Lubricants Research Facility (TFLRF) located at Southwest Research Institute (SwRI), San Antonio, Texas, performed this work during the period May 2008 through December 2008 under Contract No. DAAE-07-99-C-L053. The U.S. Army Tank-Automotive RD&E Center, Force Projection Technologies, Warren, Michigan administered the project. Mr. Luis Villahermosa (AMSRD-TAR-D/MS110) served as the TARDEC contracting officer's technical representative. Mr. Kenneth Walther (AMSRD-TAR-D/210, MS110), Fuel and Water Support Team, TARDEC, served as the project technical monitor.

The author would like to acknowledge the assistance of Messrs. Raymond Lemes, Chad Vollmer, and Max Reinhard, Jr., SwRI, for conducting the filtering testing and Mmes. Rebecca Emmot and Dianna Barrera for editing and processing the report.

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
EXECUTIVE SUMMARY	v
FOREWORD/ACKNOWLEDGMENTS.....	vi
LIST OF TABLES.....	viii
LIST OF FIGURES	viii
1.0 INTRODUCTION AND BACKGROUND	1
2.0 OBJECTIVE AND APPROACH	1
3.0 TEST FACILITY AND MATERIALS	1
4.0 TEST METHODOLOGY	2
5.0 TEST DATA	3
5.1 Examination per ¶4.5.1	3
5.2 Structural Strength	4
5.3 Single Element Test (SET)	1
5.4 Environmental Testing.....	1
6.0 CONCLUSIONS.....	4
APPENDIX	

LIST OF TABLES

<u>Table</u>	<u>Page</u>
1. Test Results of Candidate DOD Aviation Fuel Filters per MIL-PRF-52308J.....	3

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
1. Kaydon Coalescer Without Identification Markings	4
2. Kaydon Elements Failing Structural Integrity Test	4
3. Failed Single Element Test (SET) – Kaydon.....	1

1.0 INTRODUCTION AND BACKGROUND

Aviation fuel filters are required for field operations and need to be qualified per military specifications. Currently, one supplier is qualified to provide aviation fuel filters meeting MIL-PRF-52308J Amendment 2. TARDEC would like to determine if other manufacturers have product that will also pass this test protocol. Four other manufacturers were recommended by TARDEC to obtain elements from and to evaluate per MIL-PRF-52308J Amendment 2. The other manufacturers included:

- PecoFacet International
- Kaydon Corporation
- Parker Hannifin–Racor
- New Ventures, Inc.

2.0 OBJECTIVE AND APPROACH

The objective of this project is to qualify additional supplier's coalescers to MIL-F-52308J Amendment 2 at the Army approved aviation filter test facility at Southwest Research Institute (SwRI), San Antonio, TX. The government provided separators as necessary, including the single element test, and full-scale test vessels.

3.0 TEST FACILITY AND MATERIALS

The SwRI aviation filter test facility has been certified by Vic Hughes (Vic Hughes Associates, Ltd.) and approved by Force Projection Technologies (TARDEC) as an Army approved aviation filter test facility. The facility is ISO 17025 certified.

SwRI requested and procure forty-six (46) coalescer filter elements from each of the following potential vendors:

- PecoFacet Internation
- Kaydon Corporation
- Parker Hannifin – Racor
- New Ventures, Inc.

New Ventures did not have a product off-the-shelf to be evaluated for this program. Per TARDEC’s approval, Velcon provided a fourth product to evaluate that was similar to the previously qualified product.

PecoFacet elements failed the initial evaluation and they provided new elements for the re-run evaluation.

4.0 TEST METHODOLOGY

SwRI conducted, on each vendor submission, the First Article inspection as described in Section 4, ¶4.2 of MIL-PRF-52308J, and summarized in Table 1, which includes the following:

1. Three (3) samples subjected to Examination ¶4.5.1 followed by Structural Strength ¶4.5.2.
2. Two (2) samples were subjected to Examination ¶ 4.5.1 followed by Differential Pressure, Operational Performance ¶4.5.3.
3. Eighteen (18) samples were subjected to Examination ¶4.5.1 followed by Environmental ¶4.5.4, which includes the following and in this order:
 - A. Transit Drop, ¶4.5.4.1
 - B. Resistance to Fuel, High Temp, ¶4.5.4.2
 - C. Resistance to Fuel, Low Temp,¶ 4.5.4.3
 - D. Resistance to Salt Water, ¶4.5.4.4
 - E. Post-environmental Performance, ¶ 4.5.4.5

Per MIL-PRF-52308J, the test vessels are defined in ¶4.4.1 and provided by TARDEC, and the test fuel is defined in ¶ 4.4.2. Elements tested were designated as Class M elements per MIL-PRF-52308J, and were tested using Category M fuel and additive package per ¶ 4.4.2.

The exceptions to the procedures were:

The separators supplied and used for the testing were 200 mesh screen, conductive plastic end cap design, part number SI-522 supplied by Velcon Filters Inc, as an alternate design to drawing 13216E2773, approved under ECP TACV-2336.

5.0 TEST DATA

A summary of the test results is shown in Table 1, with the supporting data provided below. The data sheets for all of the evaluations are shown in the Appendix.

Table 1. Test Results of Candidate DOD Aviation Fuel Filters per MIL-PRF-52308J

Parameter	PecoFacet	PecoFacet - Rerun	Kaydon	Racor	Velcon
Examination	Pass	Fail	Pass	Pass	Pass
Structural	Fail/Pass	Pass	Fail	Pass	Pass
Single Element	Fail	Pass	Fail	Pass	Pass
Transit Drop	Pass	n/a	n/a	Pass	Pass
Resistance to Fuel – High Temperature	Pass	Fail	n/a	Pass	Pass
Resistance to Fuel – Low Temperature	Pass	Fail	n/a	Pass	Pass
Resistance to Fuel – Salt Water	Pass	Fail	n/a	Pass	Pass
Visual Post Examination	Pass	Fail	n/a	Pass	Pass
Full-Scale test	Fail	Fail	n/a	Pass	Fail

5.1 Examination per ¶4.5.1

All of the elements were visually inspected per ¶4.5.1, Table 2. All of the elements met the required specification except the Kaydon elements that did not have any identification markings on the outer sock, Figure 1.




Figure 1. Kaydon Coalescer Without Identification Markings

5.2 Structural Strength

The structural integrity of all of the candidate elements was evaluated in duplicate. All candidate elements passed this evaluation with the exception of the Kaydon elements (Figure 2). Both elements failed at between 25–30 psid. The elements are required to hold 75 psid for 5 minutes.



Figure 2. Kaydon Elements Failing Structural Integrity Test

5.3 Single Element Test (SET)

All candidate elements were evaluated per ¶4.5.3. The Kaydon element failed this evaluation after 115 minutes into the evaluation, Figure 3. Note that the failed coalescer also caused structural damaged to the separator. Since the Kaydon elements failed both the structural and SET, no further testing was performed on these elements.

The PecoFacet element failed this test and was re-run twice. All three evaluations failed the SET tests. The first element failed at glued seam, whereas the second and third SET tests both failed during the 3% water challenge.



Figure 3. Failed Single Element Test (SET) – Kaydon

5.4 Environmental Testing

The environmental testing was performed on all of the candidate elements except Kaydon. The environmental testing consisted of the following tests:

- Transit drop test
- Resistance to fuel – high temperature: 140°F for 100 hours

- Resistance to fuel – low temperature: –25°F for 100 hours
- Resistance to salt water for 72 hours
- Post-environmental performance: visual and full-scale test

For all of the tests except the transit tests, 18 elements were soaked according to the parameters described in ¶ 4.5.4.2 through 4.5.4.4.

All candidate elements passed the transit drop, resistance to fuel (both hot and cold temperature), salt water, and visual post inspection.

The PecoFacet and Velcon elements failed at the 3% water challenge. The Parker Hannifin–Racor elements passed the full test protocol. Mr. Jeff Stewart, Parker Hannifin–Racor was present to witness their full-scale test.

The re-run of the PecoFacet elements was performed and witnessed by Mr. Ron McDowell (single element test) and Mr. Charles Lindsey (full-scale test). The new elements did pass the single element and structural tests. However, measurements of the end-caps revealed many of the holes were out of tolerance (too small). The specification is 1.190 – 1.205 inches. The out-of-inspection values ranged from 1.179 to 1.860 inches, Table 2.

Table 2. PecoFacet End Cap Analysis

Element	Printed End Diameter, inches	Non-Printed End Diameter, inches	Printed End Deformation	Non-Printed End Deformation
1	1.186	1.199	No	No
2	1.182	1.200	Yes	No
3	1.186	1.200	Yes	No
4	1.182	1.202	Yes	No
5	1.182	1.198	Yes	No
6	1.181	1.200	Yes	No
7	1.199	1.179	No	Yes

8	1.196	1.183	No	Yes
9	1.179	1.199	Yes	No
10	1.179	1.197	Yes	No
11	1.201	1.201	No	No
12	1.181	1.201	Yes	Yes
13	1.202	1.183	No	Yes
14	1.196	1.180	No	Yes
15	1.204	1.183	No	Yes
16	1.200	1.181	No	Yes
17	1.200	1.182	No	Yes
18	1.185	1.199	Yes	No

During the environmental testing, deformation of the end caps occurred. It appears PecoFacet received a bad batch of end caps as only one cap per elements was deformed and discolored, Figures 4-6.



Figure 4. Deformed end cap on a PecoFacet coalescer after environmental testing



Figure 5. Discoloration of PecoFacet coalescer end caps



Figure 6. Torn o-ring in PecoFacet end cap

6.0 CONCLUSIONS

Velcon had previously qualified a product meeting MIL-PRF-52308J Amendment 2. Products from additional manufacturers were evaluated to provide TARDEC with multiple vendors. The Kaydon elements did not pass the structural nor single element tests (SET). The PecoFacet

elements failed both the single element (SET) and full-scale tests at the 3% water challenge. The re-run with new elements did pass the SET test but failed the environmental and full-scale evaluations. The Velcon elements pass all tests except the 3% water challenge during the full-scale test. The Parker Hannifin–Racor elements passed all of the tests and meet the requirements of MIL-PRF-52308J Amendment 2.

APPENDIX

5th Edition Single Element Data Sheet

Test Specification: API/IP 1581 5th Edition				SET: <input checked="" type="checkbox"/>						Date: 11/6/08			
Test No. 43				Full-Scale: <input type="checkbox"/>									
Vessel:		Filter/Coalescer: Kaydon				Separator: Velcon				Type: <input checked="" type="checkbox"/> -S <input type="checkbox"/> S-LD			
Additive Addition		Model: C220049				Model: SI522				Manufacturing Date:			
Category:		M-100 <input type="checkbox"/>				M <input checked="" type="checkbox"/>				C <input type="checkbox"/>			
Tank Volume	Gallons	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)
Beginning	9,050	A	256			D	2,0	68.5 g	629	I	1,0		
Ending		B	0,15%			B	0,15%	13.6 gal		II	15		
Used		C	15			C	15	513.9 g					
Mixing Time: 30 minutes						WISM		Before	After				
Element Conditioning:		<input checked="" type="checkbox"/> in-Situ		<input type="checkbox"/> External				94	83				
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate <input checked="" type="checkbox"/> mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate <input type="checkbox"/> mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F
Start-up	0	0	20.2	1.2	603	0	<1						71
Water 0,01%	5	0	20	1.2	604	7.6	1.5						
	10	5	20	1.7	571	7.6	1.5						
	15	10 s/s	20.2	1.8	463	7.6	2.5						
	25	20 s/s	20.2	2	582	7.6	2.5						
	35	30 s/s	20	2	604	7.6	3						72

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate <input checked="" type="checkbox"/> mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate <input checked="" type="checkbox"/> mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F
Solids Holding Test (Continued until reaching 115 kPa (22.5 psid))	35	0	20	1.5	602								72
	50	15	20	2.5				19	2		0	4L	72
		15 s/s	20.1	2.8				19	3		0.5	4L	
	65	30	20	5.1	611			19	4		0.025	4L	
		30 s/s	20.2	6				19	5		0.05	4L	
	80	45	20.2	8.2				19	6		0.15	4L	
		45 s/s	20.2	9.6				19	7		0.075	4L	
	85	50	20.2	9.6									
		60 s/s	20.2	12.2				19	8		0	4L	73
	110	75	20.1	13.7				19	9		0.15	4L	
	75 s/s	20.2	14.6				19	10		0	4L		
							19	11		0.125	4L		

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate		Water Concent. (ppm)	Solids Rate		Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp	
						■ mL/min	□ gpm		■ mg/L	□ mg/gal					□ °C	■ °F
Water Coalescence Test - 0.01%	110	0	20.2	14	627	7.6		1								74
	112	2	20	20.4		7.6		2								
	115	4	20			7.6		>12								74
	125	15														
		30 s/s														
	155	45														
	170	60 s/s														
	185	75														
		90 s/s														
	215	105														
		120 s/s														
	245	135														
		150 s/s														
Water Coalescence Test - 3%	260	0														
	262	2														
	265	5														
		10 s/s														
		20 s/s														
	290	30														

5th Edition Single Element Data Sheet

Test Specification: API/IP 1581 5th Edition					SET: <input checked="" type="checkbox"/>					Date: 11/13/08				
Test No.					Full-Scale: <input type="checkbox"/>									
Vessel:		Filter/Coalescer: Facet				Separator: Velcon				Type: <input checked="" type="checkbox"/> -S <input type="checkbox"/> S-LD				
Additive Addition		Model: TC-C0152				Model: SI522				Manufacturing Date:				
Category:		M-100 <input type="checkbox"/>				M <input checked="" type="checkbox"/>				C <input type="checkbox"/>				
Tank Volume	Gallons	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	
Beginning	9,050	A	256			D	2,0	68.5 g	629	I	1,0			
Ending		B	0,15%			B	0,15%	13.6 gal		II	15			
Used		C	15			C	15	513.9 g						
Mixing Time: 30 minutes					WISM				Before	After				
Element Conditioning:		<input checked="" type="checkbox"/> in-Situ			<input type="checkbox"/> External			95	85					
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F	
Start-up	0	0	20	4	564	0	<1						72	
Water 0,01%	5	0	20	4	600	7.6	1							
	10	5	19.9	4.6		7.6	2							
	15	10 s/s	20	5.2		7.6	2							
	25	20 s/s	20.2	6.2		7.6	4							
	35	30 s/s	20.1	7.1	638	7.6	4						73	
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F	
Solids Holding Test (Continued until reaching 115 kPa (22,5 psid))	35	0	20.1	6.1	651								73	
	50	15	20	9.9				19	2		0.2	4L	73	
			15 s/s	20.2	8.1				19	3		1.75	4L	
	65	30	20.1	8.4	651				19	4		8.875	4L	
			30 s/s	20.2	5.9				19	5		4.85	4L	
	80	45	20.2	6					19	6		7.575	4L	
			45 s/s	20.4	5.8				19	7		12.425	4L	
	85	50	20.2	5.6										
	95	60	20.3	5.8	661				19	8		11.05	4L	74
			60 s/s	20.4	5.8				19	9		9.5	4L	
110	75	20.2	5.6					19	10		8.275	4L		
		75 s/s						19	11					

++

Notes/Comments:

Test terminated at 75 minutes during solids challenge due to apparent element failure

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate	Water Concent.	Solids Rate	Filter Sample ID	Solids Concent. Affluent	Solids Concent. Effluent	Sample Size	Temp
						<input type="checkbox"/> mL/min <input type="checkbox"/> gpm	(ppm)	<input type="checkbox"/> mg/L <input type="checkbox"/> mg/gal		(mg/L)	(mg/L)		<input type="checkbox"/> °C <input type="checkbox"/> °F
Water Coalescence Test - 0.01%	110	0											
	112	2											
	115	5											
	125	15											
		30 s/s											
	155	45											
	170	60 s/s											
	185	75											
		90 s/s											
	215	105											
		120 s/s											
	245	135											
	150 s/s												
Water Coalescence Test - 3%	260	0											
	262	2											
	265	5											
		10 s/s											
		20 s/s											
	290	30											

5th Edition Single Element Data Sheet

Test Specification: API/IP 1581 5th Edition					SET: <input checked="" type="checkbox"/>							Date: 11/19/08		
Test No.							Full-Scale: <input type="checkbox"/>							
Vessel:		Filter/Coalescer: Racor					Separator: Velcon					Type: <input checked="" type="checkbox"/> -S <input type="checkbox"/> S-LD		
Additive Addition		Model: CP-20452-J					Model: SI522					Manufacturing Date:		
Category:		M-100 <input type="checkbox"/>					M <input checked="" type="checkbox"/>					C <input type="checkbox"/>		
Tank Volume	Gallons	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	
Beginning	9,050	A	256			D	2,0	68.5 g	629	I	1,0			
Ending		B	0,15%			B	0,15%	13.6 gal		II	15			
Used		C	15			C	15	513.9 g						
Mixing Time: 30 minutes							WISM		Before	After				
Element Conditioning:		<input checked="" type="checkbox"/> in-Situ			<input type="checkbox"/> External					96	86			
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate <input checked="" type="checkbox"/> mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate <input type="checkbox"/> mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F	
Start-up	0	0	20	1.8	584	0	1						70	
Water 0,01%	5	0	19.9	1.8	586	7.6	1							
	10	5	20	2.2		7.6	2							
	15	10 s/s	20.2	2.6		7.6	2							
	25	20 s/s	20	3.2		7.6	2							
	35	30 s/s	20.1	3.1	603	7.6	2						70	
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate <input checked="" type="checkbox"/> mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate <input checked="" type="checkbox"/> mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F	
Solids Holding Test (Continued until reaching 115 kPa (22.5 psid))	35	0	20	2.7	601								70	
	50	15	20	3.5				19	2		0.025	4L	71	
			15 s/s	20.1	3.7			19	3		0.05	4L		
	65	30	20	4.6	614			19	4		0	4L		
			30 s/s	20	4.9			19	5		0	4L		
	80	45	20	6.5				19	6		0	4L		
			45 s/s	20	7.2			19	7		0.05	4L		
	85	50	20	7.4										
			60 s/s	19.9	8.3	634			19	8		0.05	4L	72
	110	75	20	9.4					19	10		0.275	4L	
		75 s/s	20.1	9.5				19	11		0.45	4L		

++

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate		Water Concent. (ppm)	Solids Rate		Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp		
						■ mL/min	□ gpm		■ mg/L	□ mg/gal					□ °C	■ °F	
Water Coalescence Test - 0.01%	110	0	20	9	642	7.6		1								73	
	112	2	19.8	10.7		7.6		1									
	115	5	20	11.1		7.6		2									
	125	15	20	11.9	649	7.6		2								73	
		30 s/s	20	12.5		7.6		3									
	155	45	20	13		7.6		3									
	170	60 s/s	20.2	13.3	652	7.6		6									
	185	75	20	13.6		7.6		7									
		90 s/s	20.1	13.8		7.6		7.5									74
	215	105	20	14.1	676	7.6		2.5									
		120 s/s	20	14.2		7.6		2.5									
	245	135	20	14.5		7.6		2.5									
		150 s/s	20.1	14.7		7.6		4									
Water Coalescence Test - 3%	260	0	20.2	12	685	0		2									
	262	2	20.2	19.7		2,270		5								75	
	265	5	20	20.4		2,270		3									
		10 s/s	20.2	22.1	---	2,270		>12									
		20 s/s	20	26.3		2,270		2									
	290	30	20.1	33.7		2,270		3									75

5th Edition Single Element Data Sheet

Test Specification: API/IP 1581 5th Edition					SET: <input checked="" type="checkbox"/>						Date: 11/17/08		
Test No.							Full-Scale: <input type="checkbox"/>						
Vessel:		Filter/Coalescer: Velcon					Separator: Velcon				Type: <input checked="" type="checkbox"/> -S <input type="checkbox"/> S-LD		
Additive Addition		Model: TE08-083					Model: SI522				Manufacturing Date:		
Category:		M-100 <input type="checkbox"/>			M <input checked="" type="checkbox"/>			C <input type="checkbox"/>					
Tank Volume	Gallons	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)
Beginning	9,050	A	256			D	2,0	68.5 g	629	I	1,0		
Ending		B	0,15%			B	0,15%	13.6 gal		II	15		
Used		C	15			C	15	513.9 g					
Mixing Time: 30 minutes							WISM		Before	After			
Element Conditioning:		<input checked="" type="checkbox"/> in-Situ			<input type="checkbox"/> External					95	84		
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate <input checked="" type="checkbox"/> mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate <input type="checkbox"/> mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F
Start-up	0	0	20	3.4	548	0	1						62
Water 0,01%	5	0	19.8	3.4	547	7.6	1						
	10	5	19.9	3.6		7.6	1						
	15	10 s/s	20.2	3.9		7.6	1						
	25	20 s/s	20	4.2		7.6	1.5						
	35	30 s/s	20	4.5	545	7.6	2						61
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate <input checked="" type="checkbox"/> mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate <input checked="" type="checkbox"/> mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F
Solids Holding Test (Continued until reaching 115 kPa (22,5 psid))	35	0	19.9	4.4	547								62
	50	15	19.9	4.4				19	2		0.175	4L	62
		15 s/s	20.1	4.6				19	3		0.05	4L	
	65	30	20	4.3	562			19	4		0	4L	
		30 s/s	20.1	4.4				19	5		0	4L	
	80	45	20	4.5				19	6		0	4L	
		45 s/s	20	4.6				19	7		0.175	4L	
	85	50	20.1	4.5									
		50 s/s	20	4.9	583			19	8		0	4L	63
		60 s/s	20.2	5.1				19	9		0.05	4L	
110	75	20	6				19	10		0	4L		
	75 s/s	20.1	6.4				19	11		0	4L		

++

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate		Water Concent. (ppm)	Solids Rate		Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp		
						<input type="checkbox"/> mL/min	<input type="checkbox"/> gpm		<input type="checkbox"/> mg/L	<input type="checkbox"/> mg/gal					<input type="checkbox"/> °C	<input type="checkbox"/> °F	
Water Coalescence Test - 0.01%	110	0	20	6.5	487		7.6	2								64	
	112	2	20	6.7			7.6	2									
	115	5	20	7.7			7.6	2.5									
	125	15	20	8.7	590		7.6	3								64	
		30 s/s	20.2	8.7			7.6	3									
	155	45	20	9.2			7.6	3									
	170	60 s/s	20.2	9.2	597		7.6	3									
	185	75	20	9.6			7.6	3									
		90 s/s	20.2	9.6			7.6	3									66
	215	105	20.2	9.9	611		7.6	3									
		120 s/s	20.2	9.9			7.6	3									
	245	135	20	10.1			7.6	3									
		150 s/s	20.1	10.2			7.6	3									
Water Coalescence Test - 3%	260	0	20.1	8.3	619		0	3									
	262	2	20.2	13.9			2,270	10								68	
	265	5	19.9	16.3			2,270	2									
		10 s/s	20	18.3	613		2,270	3									
		20 s/s	20.2	24.8			2,270	11									
	290	30	20.2	30.4			2,270	11									68

5th Edition Single Element Data Sheet

Test Specification: API/IP 1581 5th Edition					SET: <input checked="" type="checkbox"/>							Date: 11/24/08		
Test No.							Full-Scale: <input type="checkbox"/>							
Vessel:		Filter/Coalescer: Velcon					Separator: Velcon					Type: <input checked="" type="checkbox"/> -S <input type="checkbox"/> S-LD		
Additive Addition		Model: TE08-083					Model: SI522					Manufacturing Date:		
Category:		M-100 <input type="checkbox"/>					M <input checked="" type="checkbox"/>					C <input type="checkbox"/>		
Tank Volume	Gallons	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	
Beginning	9,050	A	256			D	2,0	68.5 g	629	I	1,0			
Ending		B	0,15%			B	0,15%	13.6 gal		II	15			
Used		C	15			C	15	513.9 g						
Mixing Time: 30 minutes							WISM		Before	After				
Element Conditioning:		<input checked="" type="checkbox"/> in-Situ			<input type="checkbox"/> External			96		84				
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F	
Start-up	0	0	20	3.2	590	0	1						70	
Water 0,01%	5	0	20	3.1	614	7.6	1.5							
	10	5	20	3.4		7.6	2							
	15	10 s/s	20.2	3.6		7.6	2							
	25	20 s/s	20.2	4.2		7.6	3							
	35	30 s/s	20.2	4.4	601	7.6	3						69	
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate mg/L <input checked="" type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F	
Solids Holding Test (Continued until reaching 115 kPa (22.5 psid))	35	0	19.9	4	606								69	
	50	15	20	4.2				19	2		0.05	4L	70	
			15 s/s	20.2	4.2				19	3		0.025	4L	
	65	30	20.2	4.2	607				19	4		0	4L	
			30 s/s	19.8	4.2				19	5		0.1	4L	
	80	45	20	4.8					19	6		0.125	4L	
			45 s/s	20.2	5.2				19	7		0.075	4L	
	85	50	20	5.5										
	95	60	19.9	6	600				19	8		0.025	4L	70
			60 s/s	20	7.2				19	9		0.05	4L	
110	75	20	8.4					19	10		0.1	4L		
		75 s/s	20	8.5				19	11		0.125	4L		

++

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate		Water Concent. (ppm)	Solids Rate		Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp		
						<input type="checkbox"/> mL/min <input type="checkbox"/> gpm	<input type="checkbox"/> mg/L <input type="checkbox"/> mg/gal		<input type="checkbox"/> °C <input type="checkbox"/> °F								
Water Coalescence Test - 0.01%	110	0	20	8.4	487		7.6	1								71	
	112	2	20.2	9.9			7.6	2									
	115	5	20	10.2			7.6	2									
	125	15	20	11.3	590		7.6	2								71	
		30 s/s	20.2	11.9			7.6	2									
	155	45	20	12.4			7.6	2									
	170	60 s/s	20.2	13	597		7.6	3									
	185	75	19.9	13.2			7.6	3									
		90 s/s	20.2	13.8			7.6	3									73
	215	105	20	14.2	611		7.6	3									
		120 s/s	20.2	14.9			7.6	3									
	245	135	20.2	15.2			7.6	3									
	150 s/s	20.2	15.6			7.6	3										
Water Coalescence Test - 3%	260	0	20.2	10.5	619		0	3									
	262	2	19.8	20.8			2,270	4								74	
	265	5	19.9	24.2			2,270	1									
		10 s/s	19.8	29.4	613		2,270	2									
		20 s/s	20	36.6			2,270	5									
	290	30	19.9	45.9			2,270	7									74

5th Edition Single Element Data Sheet

Test Specification: API/IP 1581 5th Edition					SET: <input checked="" type="checkbox"/>							Date: 11/27/08			
Test No.					Full-Scale: <input type="checkbox"/>										
Vessel:		Filter/Coalescer: Facet			Separator: Velcon			Type: <input checked="" type="checkbox"/> -S <input type="checkbox"/> S-LD							
Additive Addition		Model: TC-C0152			Model: SI522			Manufacturing Date:							
Category:		M-100 <input type="checkbox"/>			M <input checked="" type="checkbox"/>			C <input type="checkbox"/>							
Tank Volume	Gallons	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)		
Beginning	9,050	A	256			D	2,0	68.5 g	629	I	1,0				
Ending		B	0,15%			B	0,15%	13.6 gal		II	15				
Used		C	15			C	15	513.9 g							
Mixing Time: 30 minutes					WISM			Before	After						
Element Conditioning:		<input checked="" type="checkbox"/> in-Situ			<input type="checkbox"/> External			97	85						
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate <input checked="" type="checkbox"/> mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate <input checked="" type="checkbox"/> mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F		
Start-up	0	0	20	4.1	588	0	1						72		
Water 0,01%	5	0	20	4.2	597	7.6	1.5								
	10	5	20	5.3		7.6	2								
	15	10 s/s	20	6.1		7.6	2								
	25	20 s/s	20	7		7.6	2								
	35	30 s/s	20	7.2	576	7.6	2						70		
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate <input checked="" type="checkbox"/> mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate <input checked="" type="checkbox"/> mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F		
Solids Holding Test (Continued until reaching 115 kPa (22.5 psid))	35	0	20	6.9	590								70		
	50	15	20	9.3				19	2		0.125	4L	70		
			15 s/s	20.1	9.2				19	3		0	4L		
	65	30	20	11.1	591				19	4		0	4L		
			30 s/s	20.1	11.4					19	5		0.05	4L	
	80	45	19.9	12.4					19	6		0.025	4L		
			45 s/s	20.1	12.6					19	7		0	4L	
	85	50	20	13.1											
	95	60	20	13.7	597					19	8		0.05	4L	70
			60 s/s	20	14.1						19	9		0.025	4L
110	75	19.9	14.6						19	10		0.075	4L		
		75 s/s	20	14.9						19	11		0	4L	

++

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate		Water Concent. (ppm)	Solids Rate		Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp		
						■ mL/min	□ gpm		■ mg/L	□ mg/gal					□ °C	■ °F	
Water Coalescence Test - 0.01%	110	0	19.9	14.5	594	7.6	1.5									70	
	112	2	20	15.5		7.6	2										
	115	5	20.2	17.7		7.6	2										
	125	15	20.1	19.8	599	7.6	2									70	
		30 s/s	20.2	20.3		7.6	3										
	155	45	19.8	21.3		7.6	3										
	170	60 s/s	20.2	21.8	607	7.6	3										
	185	75	20	22.7		7.6	3										
		90 s/s	20.2	22.8		7.6	3										70
	215	105	20	23.8	605	7.6	3										
		120 s/s	20	23.7		7.6	3										
	245	135	19.8	24.5		7.6	4										
	150 s/s	20.2	24.3		7.6	4											
Water Coalescence Test - 3%	260	0	20.2	22	608	0	3										
	262	2	19.8	35.1		2,270	4									71	
	265	5	19.9	37.5		2,270	>20										
		10 s/s	20	42.5	---	2,270	20										
		20 s/s	20	49.2		2,270	>60										
	290	30	20	58.8		2,270	>60										71

5th Edition Full Scale Data Sheet

Test Specification: API/IP 1581 5th Edition					SET: <input type="checkbox"/>							Date: 3/3/09	
Test No.					Full-Scale: <input checked="" type="checkbox"/>								
Vessel:		Filter/Coalescer: Facet			Separator: Velcon			Type: <input checked="" type="checkbox"/> -S <input type="checkbox"/> S-LD					
Additive Addition		Model: TC-C0152			Model: SI522			Manufacturing Date:					
Category:		M-100 <input type="checkbox"/>			M <input checked="" type="checkbox"/>			C <input type="checkbox"/>					
Tank Volume	8000	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)
		A	256			D	2,0	60.5	445	I	1,0		
		B	0,15%			B	0,15%	12		II	15		
		C	15			C	15	454.2					
		D	2,0										
Mixing Time: 30 minutes					WISM			Before	After add.				
Element Conditioning:		<input checked="" type="checkbox"/> in-Situ			<input type="checkbox"/> External								
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min □ gpm	Water Concent. (ppm)	Solids Rate ■ mg/L □ mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp □ °C ■ °F
Media Migration	0	0	37	0.9	58								59
	10	10	36	0.9									
	20	20	38	1									
	30	30	38	0.9	180				1				60
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min □ gpm	Water Concent. (ppm)	Solids Rate ■ mg/L □ mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp □ °C ■ °F
0.01% Water Addition	30	0	350	5.4		0	1						
	35	5	352	7	364	132.5	3						
	40	10	351	7.2		132.5	2						61
	45	15 s/s	350	7.7		132.5							61
	50	20	355	8		132.5	6						62
	60	30	353	8.4	417	132.5							62
	60	30 s/s	357	8.7		132.5	6						
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min □ gpm	Water Concent. (ppm)	Solids Rate ■ mg/L □ mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp □ °C ■ °F
Solids Holding Testing	60	0	354	8.2				0				4L	
	75	15	349	9.5				19	2		0.1	4L	
		15 s/s	350	9.6				19	3		0.175	4L	64
	90	30	349	10.2				19	4		0.2	4L	
		30 s/s	347	10.5				19	5		0.15	4L	
	105	45	355	11.3				19	6		0.125	4L	66
		45 s/s	349	11.4				19	7		0.125	4L	

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate		Solids Rate mg/L mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp	
						■ mL/min	□ gpm						□ °C	■ °F
0.01% Water Addition	105	0	354	11.4	440	0	2							66
	107	2	352	12.5		132.5	9							67
	110	5	352	12.6		132.5	7							66
	120	15	350	12.8	462	132.5	9							67
	135	30 s/s	349	12.8		132.5	10							66
	150	45	349	13.3		132.5	8							66
	165	60 s/s	349	13.3	504	132.5	9							66
	180	75	350	13.5		132.5	8							66
	195	90 s/s	349	13.5		132.5	10							66
Water Coalescence Test - 3%	195	0	353	12.1	515	0	2							67
	197	2	349	16.3		39.7 lpm	>24							66
	200	5	347	16.6		39.7 lpm	>60							66
	205	10												
	210	15												

5th Edition Full Scale Data Sheet

Test Specification: API/IP 1581 5th Edition					SET: <input type="checkbox"/>						Date: 12/22/08			
Test No.		Filter/Coalescer: Facet			Separator: Velcon			Type: <input checked="" type="checkbox"/> -S <input type="checkbox"/> S-LD						
Vessel:		Model: TC-C0152			Model: S1522			Manufacturing Date:						
Additive Addition														
Category:		M-100 <input type="checkbox"/>			M <input checked="" type="checkbox"/>			C <input type="checkbox"/>						
Tank Volume	Gallons	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	
	10,440	A	256			D	2,0	79 g	910	I	1,0			
		B	0,15%			B	0,15%	15.7 gal		II	15			
		C	15			C	15	592.8 g						
		D	2,0											
Mixing Time: 30 minutes					WISM			Before	After add.					
Element Conditioning:		<input checked="" type="checkbox"/> in-Situ			<input type="checkbox"/> External			94	83					
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate <input type="checkbox"/> mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C ■ °F	
Media Migration	0	0	35	1.2	590								45	
	10	10	33	1.5										
	20	20	34	1.5										
	30	30	36	1.5	582				1				45	
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate ■ mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C ■ °F	
0.01% Water Addition	30	0	350	606	557	0	2							
	35	5	351	7.7	555	132.5	1							
	40	10	350	8		132.5	2						45	
	45	15 s/s	350	8.1		132.5							45	
	50	20	348	8.4		132.5	2						45	
	60	30	352	8.9	551	132.5							45	
	60	30 s/s	350	8.5		132.5	2							
Phase	Cum. Test Time (minutes)	++Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate ■ mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C ■ °F	
Solids Holding Testin	60	0	350	8.1				0				4L		
	75	15	350	10.1				19	2			0.025	4L	
		15 s/s	350	9.9				19	3			0.025	4L	45
	90	30	348	11.7				19	4			0.15	4L	
		30 s/s	349	11.7				19	5			0.075	4L	
	105	45	350	13.6				19	6			0.1	4L	45
		45 s/s	351	13.4				19	7			0.1	4L	

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate		Water Concent. (ppm)	Solids Rate		Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp	
						■ mL/min	□ gpm		■ mg/L	□ mg/gal					□ °C	■ °F
0.01% Water Addition	105	0	350	13	536		0	2								46
	107	2	349	14.5			132.5	2								46
	110	5	350	14.8			132.5	3								46
	120	15	348	15.2	542		132.5	3								46
	135	30 s/s	350	15.2			132.5	3								46
	150	45	350	16			132.5	4								46
	165	60 s/s	350	15.9	526		132.5	4								46
	180	75	349	16.7			132.5	4								47
	195	90 s/s	351	16.7			132.5	4								47
Water Coalescence Test - 3%	195	0	350	14.5	492		0	1								47
	197	2	353	29.1			39.7 lpm	>24								48
	200	5	350	30.7			39.7 lpm	>24								48
	205	10	347	36.4	540		39.7 lpm	>24								48
	210	15	351	40.2			39.7 lpm	>24								48

5th Edition Full Scale Data Sheet

Test Specification: API/IP 1581 5th Edition				SET: <input type="checkbox"/>						Date: 12/17/08			
Test No.				Full-Scale: <input checked="" type="checkbox"/>									
Vessel:		Filter/Coalescer: Racor CP-20452-J				Separator: Velcon				Type: <input checked="" type="checkbox"/> -S <input type="checkbox"/> S-LD			
Additive Addition		Model: CP-20452-J				Model: SI522				Manufacturing Date:			
Category:		M-100 <input type="checkbox"/>				M <input checked="" type="checkbox"/>				C <input type="checkbox"/>			
Tank Volume	Gallons	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)
	10,440	A	256			D	2,0	79 g	581	I	1,0		
		B	0,15%			B	0,15%	15.7 gal		II	15		
		C	15			C	15	592.8 g					
		D	2,0										
Mixing Time: 30 minutes						WISM		Before	After add.				
Element Conditioning:		<input checked="" type="checkbox"/> in-Situ		<input type="checkbox"/> External				96	86				
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate ■ mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C ■ °F
Media Migration	0	0	35	0.5	523								54
	10	10	35	0.5									
	20	20	35	0.5									
	30	30	35	0.5	521				1				54
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate ■ mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C ■ °F
0.01% Water Addition	30	0	351	2.9		0	2						
	35	5	349	3.7		132.5	7						
	40	10	351	3.9		132.5	2						51
	45	15 s/s	350	4.2		132.5	2						51
	50	20	350	4.3		132.5	2						51
	60	30	352	4.4		132.5	2						50
Phase	Cum. Test Time (minutes)	++Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate ■ mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C ■ °F
Solids Holding Testin	60	0	350	4.1				0				4L	
	75	15	351	5.8				19	2		0.1	4L	
	115	15 s/s	349	5.8				19	3		0	4L	50
	90	30	349	7.7				19	4		0.175	4L	
		30 s/s	349	7.7				19	5		0	4L	
	105	45	348	9				19	6		0	4L	50
		45 s/s	349	9.2				19	7		0.075	4L	

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate		Water Concent. (ppm)	Solids Rate		Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp	
						■ mL/min	□ gpm		■ mg/L	□ mg/gal					□ °C	■ °F
0.01% Water Addition	105	0	352	8.9	439	0		1								50
	107	2	348	10.1		132.5		1								51
	110	5	350	10.1		132.5		2								51
	120	15	350	10.2	435	132.5		2								51
	135	30 s/s	350	10.2		132.5		2								51
	150	45	349	10.5		132.5		1								51
	165	60 s/s	350	10.5	425	132.5		2								51
	180	75	350	10.8		132.5		1								51
	195	90 s/s	350	10.5		132.5		2							52	
Water Coalescence Test - 3%	195	0	350	9.6	420	0		1								52
	197	2	353	17.7		39.7 lpm		4								52
	200	5	348	18.5		39.7 lpm		3								52
	205	10	348	21.1	430	39.7 lpm		4								52
	210	15	349	22.6		39.7 lpm		4								52

5th Edition Full Scale Data Sheet

Test Specification: API/IP 1581 5th Edition					SET: <input type="checkbox"/>							Date: 12/13/08	
Test No.					Full-Scale: <input checked="" type="checkbox"/>								
Vessel:		Filter/Coalescer: Velcon					Separator: Velcon					Type: <input checked="" type="checkbox"/> -S <input type="checkbox"/> S-LD	
Additive Addition		Model: TE08-083					Model: SI522					Manufacturing Date:	
Category:		M-100 <input type="checkbox"/>			M <input checked="" type="checkbox"/>			C <input type="checkbox"/>					
Tank Volume	Gallons	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)	Additive	Conc. (Mg/L)	Amount Added	k (pS/m)
	10,440	A	256			D	2,0	79 g	910	I	1,0		
		B	0,15%			B	0,15%	15.7 gal		II	15		
		C	15			C	15	592.8 g					
		D	2,0										
Mixing Time: 30 minutes					WISM		Before	After add.					
Element Conditioning:		<input checked="" type="checkbox"/> in-Situ			<input type="checkbox"/> External			98	86				
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate <input type="checkbox"/> mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F
Media Migration	0	0	37.1	1	581								57
	10	10	36.5	1.2									
	20	20	35.9	1.2									
	30	30	35.7	1.1	511				1				57
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate ■ mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F
0.01% Water Addition	30	0	350	4.5	413	0	2.5						
	35	5	350	5.1	427	132.5	3.5						
	40	10	349	5.2		132.5	3						56
	45	15 s/s	349	5.3		132.5							57
	50	20	349	5.4		132.5	4						57
	60	30	348	5.5	427	132.5							57
	60	30 s/s	350	5.5		132.5	4						
Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate ■ mL/min <input type="checkbox"/> gpm	Water Concent. (ppm)	Solids Rate ■ mg/L <input type="checkbox"/> mg/gal	Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp <input type="checkbox"/> °C <input checked="" type="checkbox"/> °F
Solids Holding Testing	60	0	350	5.3				0				4L	
	75	15	349	6				19	2			0	4L
	115	15 s/s	350	6				19	3			0	4L
	90	30	349	6.6				19	4			0.025	4L
		30 s/s	350	6.5				19	5			0.1	4L
	105	45	350	7.3				19	6			0.025	4L
		45 s/s	351	7.2				19	7			0.025	4L

Phase	Cum. Test Time (minutes)	Time (minutes)	Fuel Flow Rate (gpm)	ΔP (psid)	k (pS/m)	Water Flow Rate		Water Concent. (ppm)	Solids Rate		Filter Sample ID	Solids Concent. Affluent (mg/L)	Solids Concent. Effluent (mg/L)	Sample Size	Temp	
						<input type="checkbox"/> mL/min	<input type="checkbox"/> gpm		<input type="checkbox"/> mg/L	<input type="checkbox"/> mg/gal					<input type="checkbox"/> °C	<input type="checkbox"/> °F
0.01% Water Addition	105	0	351	7.1	498		0	2								61
	107	2	350	7.9			132.5	2								62
	110	5	350	7.8			132.5	2								62
	120	15	351	7.7	510		132.5	2								62
	135	30 s/s	350	7.7			132.5	2								63
	150	45	350	7.8			132.5	3								63
	165	60 s/s	350	7.8	504		132.5	2								63
	180	75	350	7.9			132.5	2								65
	195	90 s/s	350	7.8			132.5	2								65
Water Coalescence Test - 3%	195	0	350	7.1	560		0	2								66
	197	2	349	11			39.7 lpm	>24								66
	200	5	350	11.1			39.7 lpm	>24								67
	205	10	349	11.5	499		39.7 lpm	>24								67
	210	15	350	11.9			39.7 lpm	>24								67