US Army Corps
of Engineers
Construction Engineering
Research Laboratory

USACERL TECHNICAL REPORT E-89/07
February 1989
AMC Energy System Modernization

AD-A205 673

An Energy Forecasting and Analysis System for the U.S. Army Materiel Command

by
Michael J. Binder

The Army has been assigned energy reduction goals with a base year of FY85 and a target year of FY95. In the interim, energy managers are required to assess the effectiveness of energy conservation efforts in terms of progress toward attaining these goals.

Direct comparison of current and base fiscal year energy consumption data is not a satisfactory method for evaluating energy conservation measures, as the effectiveness of these efforts may easily appear enhanced or diminished due to differences in weather and level of production between the current and base fiscal years. For a realistic assessment, energy managers need a mathematically sound methodology to "filter out" the effects caused by year-to-year differences in weather and production levels.

The U.S. Army Materiel Command asked the U. S. Army Construction Engineering Research Laboratory (USACERL) to produce such a method for use in energy management at the Major Command (MACOM) level. In response, USACERL has developed the Energy Forecasting and Analysis System (EFAS), a computer-based tool that uses multiple regression analysis. EFAS allows MACOM-level energy managers to establish annual energy consumption goals for individual installations and Major Subordinate Commands, and to assess progress toward achieving those goals based on energy consumption patterns.

DTIC
ELECTE
MAR 2 9 1989
S D
D

Approved for public release; distribution is unlimited.

89 3 27 054

The contents of this report are not to be used for advertising, publication, or promotional purposes. Citation of trade names does not constitute an official indorsement or approval of the use of such commercial products. The findings of this report are not to be construed as an official Department of the Army position, unless so designated by other authorized documents.

DESTROY THIS REPORT WHEN IT IS NO LONGER NEEDED
DO NOT RETURN IT TO THE ORIGINATOR

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE

REPORT DOCUMENTATION PAGE

Form Approved
OMB No 0704 0188
Exp Date Jun 30 1986

1a REPORT SECURITY CLASSIFICATION Unclassified	1b RESTRICTIVE MARKINGS
2a SECURITY CLASSIFICATION AUTHORITY	3 DISTRIBUTION/AVAILABILITY OF REPORT Approved for public release; distribution is unlimited.
2b DECLASSIFICATION/DOWNGRADING SCHEDULE	
4 PERFORMING ORGANIZATION REPORT NUMBER(S) USACERL TR E-89/07	5 MONITORING ORGANIZATION REPORT NUMBER(S)
6a NAME OF PERFORMING ORGANIZATION U.S. Army Construction Engr Research Laboratory 6b OFFICE SYMBOL (If applicable) CECER-ES	7a NAME OF MONITORING ORGANIZATION
6c ADDRESS (City, State, and ZIP Code) P.O. Box 4005 Champaign, IL 61824-1305	7b ADDRESS (City, State, and ZIP Code)
8a NAME OF FUNDING/SPONSORING ORGANIZATION USAEHSC 8b OFFICE SYMBOL (If applicable) CEHSC-FU	9 PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER
8c. ADDRESS (City, State, and ZIP Code) Fort Belvoir, VA 22060	10 SOURCE OF FUNDING NUMBERS PROGRAM ELEMENT NO: 4A162781 PROJECT NO: AT45 TASK NO: B WORK UNIT ACCESSION NO: 012

11 TITLE (Include Security Classification)
An Energy Forecasting and Analysis System for the U.S. Army Materiel Command (U)

12 PERSONAL AUTHOR(S)
Binder, Michael J.

13a TYPE OF REPORT	13b TIME COVERED	14 DATE OF REPORT (Year, Month, Day)	15 PAGE COUNT
final	FROM _____ TO _____	1989, February	31

16 SUPPLEMENTARY NOTATION
Copies are available from the National Technical Information Service
Springfield, VA 22161

17 COSATI CODES			18 SUBJECT TERMS (Continue on reverse if necessary and identify by block number)
FIELD	GROUP	SUB-GROUP	Army Materiel Command, energy consumption
10	01		Energy Forecasting and Analysis System, regression analysis

19 ABSTRACT (Continue on reverse if necessary and identify by block number)

The Army has been assigned energy reduction goals with a base year of FY85 and a target year of FY95. In the interim, energy managers are required to assess the effectiveness of energy conservation efforts in terms of progress toward attaining these goals.

Direct comparison of current and base fiscal year energy consumption data is not a satisfactory method for evaluating energy conservation measures, as the effectiveness of these efforts may easily appear enhanced or diminished due to differences in weather and level of production between the current and base fiscal years. For a realistic assessment, energy managers need a mathematically sound methodology to "filter out" the effects caused by year-to-year differences in weather and production levels.

(Cont'd)

20 DISTRIBUTION/AVAILABILITY OF ABSTRACT ☐ UNCLASSIFIED/UNLIMITED ☒ SAME AS RPT ☐ DTIC USERS	21 ABSTRACT SECURITY CLASSIFICATION UNCLASSIFIED
22a NAME OF RESPONSIBLE INDIVIDUAL Dana Finney	22b TELEPHONE (Include Area Code) (217) 352-6511 x 389 22c OFFICE SYMBOL CECER-IMT

DD FORM 1473, 84 MAR — 83 APR edition may be used until exhausted. All other editions are obsolete.

SECURITY CLASSIFICATION OF THIS PAGE

UNCLASSIFIED

(1)

Block 19. (Cont'd)

The U. S. Army Materiel Command asked the U. S. Army Construction Engineering Research Laboratory (USACERL) to produce such a method for use in energy management at the Major Command (MACOM) level. In response, USACERL has developed the Energy Forecasting and Analysis System (EFAS), a computer-based tool that uses multiple regression analysis. EFAS allows MACOM-level energy managers to establish annual energy consumption goals for individual installations and Major Subordinate Commands, and to assess progress toward achieving those goals based on energy consumption patterns.

FOREWORD

This work was performed for the U. S. Army Engineering and Housing Support Center (USAEHSC) under Project 4A162781AT45, "Energy and Energy Conservation"; Task B, "Installation Energy Conservation"; Work Unit 012, "AMC Energy System Modernization." Mr. B. Wasserman, CEHSC-FU, was the USAEHSC Technical Monitor.

The work was performed by the Energy Systems Division (ES) of the U. S. Army Construction Engineering Research Laboratory (USACERL). Dr. G. R. Williamson is Chief, ES. The USACERL technical editor was Dana Finney, Information Management Office.

The EFAS System was programmed in Microsoft Quick BASIC by David T. McKay. Enhancements were made by Jeffery Morton. Appreciation for their efforts is expressed to both.

COL Carl O. Magnell is Commander and Director of USACERL, and Dr. L. R. Shaffer is Technical Director.

Accesion For
NTIS CRA&I ☑
DTIC TAB ☐
Unannounced ☐
Justification
By
Distribution /
Availability Codes
Dist | Avail and/or Special
A-1

CONTENTS

		Page
	DD FORM 1473	1
	FOREWORD	3
	LIST OF TABLES AND FIGURES	5
1	INTRODUCTION	7
	Background	
	Objective	
	Approach	
	Mode of Technology Transfer	
2	SUMMARY OF THE MULTIPLE REGRESSION TECHNIQUE	9
3	DEVELOPMENT OF EFAS	11
	Previous Studies	
	Incentives for Developing EFAS	
	Change in the Electrical Energy Consumption Conversion Factor	
	Problems Associated With Fixed Database Regression Analysis	
4	EFAS DATABASE AND FEATURES	15
	Initial Database Details	
	Updating the Regression Equations	
	EFAS Output Details	
5	EFAS AS AN ENERGY MANAGEMENT TOOL	24
	Energy Consumption Goal-Setting and Monitoring	
	Building Energy Glide Path Determination	
	Sample Calculation	
6	CONCLUSIONS AND RECOMMENDATIONS	28
	DISTRIBUTION	

TABLES

Number		Page
1	NOAA Weather Station Locations--AMCCOM Installations	17
2	NOAA Weather Station Locations--DESCOM Installations	18
3	NOAA Weather Station Locations--TECOM Installations	18
4	NOAA Weather Station Locations--Other Installations	19
5	EFAS FY86 Regression Equations--AMCCOM Installations	19
6	EFAS FY86 Regression Equations--DESCOM Installations	20
7	EFAS FY86 Regression Equations--TECOM Installations	20
8	EFAS FY86 Regression Equations--Other Installations	21
9	EFAS FY87 Regression Equations--AMCCOM Installations	21
10	EFAS FY87 Regression Equations--DESCOM Installations	22
11	EFAS FY87 Regression Equations--TECOM Installations	22
12	EFAS FY87 Regression Equations--Other Installations	23
13	Glide Path Comparison Data--Indiana AAP	27

FIGURES

1	Contractor Labor Force Variation at Volunteer AAP	14
2	FY86 Energy Consumption and Glide Path for Indiana AAP	27

AN ENERGY FORECASTING AND ANALYSIS SYSTEM FOR THE U.S. ARMY MATERIEL COMMAND

1 INTRODUCTION

Background

The Army has been assigned energy reduction goals with a base year of FY85 and a target year of FY95. These goals call for (1) an 8 percent reduction in existing building energy consumption (Btu per square foot) and (2) a 10 percent reduction in industrial process energy intensity (Btu/productivity indicator). Industrial process energy is defined as "the facilities energy utilized in the direct production or rehabilitation of equipment or goods".[1] Any other type of facilities energy consumption (and industrial process energy consumption where appropriate productivity indicators cannot be identified), is to be considered building energy and managed on a Btu per square foot basis.

To meet these goals, energy managers are tasked with identifying potential energy conservation opportunities and implementing those which prove cost-effective. They also are required to assess the effectiveness of energy conservation efforts in terms of progress toward achieving energy consumption reduction goals.

Direct comparison of energy consumption data for the current fiscal year with the base year data is not a satisfactory method for evaluating energy conservation efforts because it does not account for differences in weather and production levels between the two fiscal years. As a result, the effectiveness of an organization's conservation measures may appear enhanced or diminished with respect to actual performance. This type of result would not affect industrial process energy management at installations that have defined appropriate productivity indicators, because the separate management of this energy on the basis of Btu per productivity indicator would account for differences in production levels. Also, it could be assumed that industrial process energy consumption is not directly responsive to variations in weather data. However, it is very difficult to identify appropriate productivity indicators and this has been done successfully in only a very limited number of cases. For the most part, differences in production levels between current and base fiscal years make direct comparison of energy consumption data ineffectual. In all cases, differences in weather data between current and base fiscal years prevent a realistic assessment of conservation efforts using such a direct comparison.

To make valid assessments, energy managers require a mathematically sound methodology to "filter out" the effects caused by year-to-year differences in weather and production levels. Such a method would allow managers to make comparisons between energy consumption patterns as opposed to actual energy consumption data. Previous studies have shown the statistical technique of multiple regression analysis to be an effective tool for characterizing energy consumption patterns involving variations

[1] Department of Defense, Defense Energy Program Policy Memorandum (DEPPM) 86-3, (16 April 1986).

in weather and production levels.[2] Based on these findings, the U. S. Army Materiel Command (AMC) asked the U. S. Army Construction Engineering Research Laboratory (USACERL) to develop a computer system that would use multiple regression analysis for energy management at the Major Command (MACOM) level.

Objective

The objective of this study was to develop an automated Energy Forecasting and Analysis System (EFAS) based on multiple regression analysis that would allow MACOM-level energy managers to (1) establish annual energy consumption goals for individual installations and Major Subordinate Commands (MSCs) and (2) assess progress toward attaining energy reduction goals based on energy consumption patterns.

Approach

Energy consumption, heating degree days (HDD), cooling degree days (CDD), and labor force (LBRFRC) data were gathered from 59 AMC installations. Multiple regression analysis was used to determine which of the three potential independent variables (HDD, CDD, LBRFRC) were significant at each installation. The AMC data comprise the EFAS database, which was developed using BASIC programming language. The EFAS software is designed to allow managers to (1) update regression equations as new data become available, (2) estimate initial and adjusted energy consumption and compare these values with actual consumption on monthly, quarterly, and annual bases, and (3) automatically generate the results for an individual installation, individual MSC, or for the entire AMC.

Mode of Technology Transfer

EFAS is being used by the AMC Headquarters Energy Office. The regression analysis concept and glide path adjustment method described in this report could be adapted for effective energy management strategies at other MACOMs.

[2] B. Sliwinski and E. Elischer, *Analysis of Facilities' Energy Use Patterns*, Technical Report E-186/ADA132527 (U.S. Army Construction Engineering Research Laboratory [USACERL], 1983); B. Sliwinski, *A Model of U.S. Army Materiel Command (AMC) Energy Consumption, Volume I: Development of Monthly Energy Consumption Equations*, Technical Report E-86/02/ADA167366 (USACERL, 1986).

2 SUMMARY OF THE MULTIPLE REGRESSION TECHNIQUE

The multiple regression technique allows a quantitative analysis of the relationship between a "dependent" variable (to be predicted or explained) and one or more "independent" variables (changes to which the dependent variable is responsive). This technique produces a mathematical expression, called a "regression equation," that predicts the value of the dependent variable by knowing the values of the independent variables. It also provides statistics that quantify the explanatory power of the regression equation, the expected errors of this equation, and the statistical significance of each independent variable.

Consider the case in which a dependent variable Y is assumed to be a linear function of only one independent variable X. The extension to more than one independent variable, while more complex mathematically, is identical in concept to the simpler one-independent-variable case. The linear relationship between Y and X may be expressed as:

$$Y_p = B_0 + B_1 \cdot X \qquad \text{[Eq 1]}$$

where:

Y_p = predicted value of Y

B_0, B_1 = parameters whose values are to be determined by multiple regression analysis.

For each value of X, (X_i), there will be an associated predicted value of Y, (Y_{Pi}), and an associated actual value of Y, (Y_i). The error (e_i) is defined as the difference between the actual and predicted values:

$$e_i = Y_i - Y_{Pi} \qquad \text{[Eq 2]}$$

Multiple regression analysis determines values for the parameters B_0 and B_1 in a way that minimizes the sum of the squares of the errors ($\Sigma\ e_i^2$).

As a first step in the regression analysis, B_1 can be set equal to zero and B_0 set equal to the mean value of Y, (Y_M), over the data range considered (i.e., $Y_{Pi} = Y_M$ for all X_i). The resulting errors can be calculated ($e_i = Y_i - Y_M$), squared, and summed over all the values of Y_i, producing a value called the "Sum of Squares About the Mean" (SS about mean). The next step in regression analysis is to determine values for both B_0 and B_1 in such a way as to minimize the sum of the squares of the errors (SS error). The difference between (SS about mean) and (SS error) is called the "Sum of Squares Due to Regression" (SS due to regression):

$$\text{(SS due to regression)} = \text{(SS about mean)} - \text{(SS error)} \qquad \text{[Eq 3]}$$

The ratio of (SS due to regression) to (SS about mean) is called the "Correlation Coefficient" (R^2):

$$R^2 = (\text{SS due to regression}) / (\text{SS about mean}) \qquad \text{[Eq 4]}$$

Thus, R^2 represents the percentage of variance of the dependent variable which is explained by the variance of the independent variables. The closer the value R^2 is to unity, the better the predictive ability of the regression equation. The Mean Square Error (MS error) is defined as:

$$(\text{MS error}) = (\text{SS error}) / (n - q) \qquad \text{[Eq 5]}$$

where: n = number of data points

q = number of parameters to be determined by regression analysis (e.g., $q = 2$ for the case of one independent variable).

The Standard Error (σ) is defined as the square root of (MS error):

$$\sigma = \sqrt{(\text{MS error})} \qquad \text{[Eq 6]}$$

Equations 5 and 6 indicate that, in order to *minimize error, the multiple regression* analysis should be performed using the largest number of data points and the least number of independent variables possible consistent with obtaining a reasonable value of R^2.

3 DEVELOPMENT OF EFAS

Previous Studies

In a study of facilities energy use patterns,[3] multiple regression analysis was used to analyze hourly energy consumption data taken between 1976 and 1979 for 70 buildings at Fort Carson, CO, Fort Hood, TX, and Fort Belvoir, VA. The results of the study indicated that multiple regression analysis could be used to provide reasonable estimates of energy consumption for aggregates of 10 or more buildings based on HDD, CDD, and building square footage by building type. Building type classifications used in the study included family housing, troop housing, and administration/training, dining, medical/dental, product maintenance, community, and storage facilities.

Multiple regression analysis was also used in developing equations to relate energy consumption to weather and process parameters on a monthly basis for the Armament Munitions and Chemical Command (AMCCOM), and on a quarterly basis for the Depot Systems Command (DESCOM).[4] AMCCOM and DESCOM are MSCs of AMC. Regression equations were developed for 23 AMCCOM and 11 DESCOM installations. The regression equations for AMCCOM installations were based on data for the range FY75 to FY82, whereas those for DESCOM installations were based on the data range FY75 to FY83. Results of the analysis indicated that HDD was a significant independent variable at all installations. CDD was found to be a significant variable at only a very few installations, all located in hot climates. The only process parameter found to provide significant increases in the correlation coefficient when entered into the monthly regression equations was the contractor labor force (LBRFRC). This parameter was significant for about 50 percent of the AMCCOM installations. Attempts to develop regression equations for DESCOM installations on a monthly basis met with only very limited success.

Incentives for Developing EFAS

The regression equations developed for AMCCOM and DESCOM installations were used by the AMC Headquarters (HQ) Energy Office during FY84 and FY85 to assess the effectiveness of energy conservation efforts at those installations for which suitable equations had been developed. Calculations during this period were performed manually and data storage was by hard copy. The initial incentive for developing EFAS was to eliminate these sources of inefficiency by automating the calculations and data manipulation associated with using the equations and by providing magnetic media storage.

The AMC HQ Energy Office also asked that the monthly energy consumption regression equations be expanded to include all AMCCOM and DESCOM installations as well as those in the other seven AMC MSCs. These MSCs include the Aviations Systems Command (AVSCOM), Communications/Electronics Command (CECOM), Laboratory Command (LABCOM), Missile Command (MICOM), Tank - Automotive Command (TACOM), Test and Evaluation Command (TECOM), and Troop Support Command (TROSCOM). The initial system requirements called for comparisons of actual energy consumption with estimated energy consumption as given by the regression equations, presented on monthly, quarterly, and annual bases for individual installations, individual MSCs, or all of AMC. These incentives and system requirements formed the driving

[3]B. Sliwinski and E. Elischer.
[4]B. Sliwinski.

force for the early stages of EFAS development. Other factors that influenced the research effort and contributed to the capabilities of the final product are discussed in the rest of this chapter.

Change in the Electrical Energy Consumption Conversion Factor

The event having the largest impact on EFAS development was a Department of Defense (DOD) policy change that became effective in FY86.[5] This directive changed the "source" conversion factor (11,600 Btu/kWh)* to the "site" conversion factor (3413 Btu/kWh) for electrical energy consumption reporting to the Defense Energy Information System (DEIS). Since all regression equations developed to date had been based on historical total energy consumption data calculated using the "source" conversion factor, this change rendered them invalid. This situation required USACERL to retrieve the original electrical consumption data reported in kWh, convert these data to MBtu using the "site" conversion factor, and sum over all of the various types of energy consumption to obtain new energy consumption totals. Regression analysis was then performed on the new total energy consumption data and new regression equations were developed. These new equations showed an increased significance of the HDD variable and decreased significance of the CDD and LBRFRC variables. In some cases, CDD and/or LBRFRC did not appear in the new regression equations, whereas they had appeared in the equations based on "source" conversion energy consumption totals.

Despite the negative impact this change had on EFAS development, it also produced some benefits. Total facilities energy consumption generally includes electrical energy consumption and heating fuel consumption (e.g., natural gas). Heating fuel consumption is well correlated with HDD and usually does not exhibit uncorrelated steady increases with time. Hence, conservation efforts in the area of heating fuel consumption are fully reflected as decreases in total energy consumption pattern. Electrical energy consumption, however, does normally exhibit uncorrelated steady increases with time due to events such as increased use of computer equipment and the associated temperature and humidity control requirements and, in Army industrial facilities, the trend to use energy-intensive production equipment to replace manual labor (e.g., robotics) for economy. Conservation efforts in the area of electrical energy consumption may therefore be masked or even overshadowed by these uncorrelated increases with time, and may not be reflected as decreases in the total energy consumption pattern. The change to the "site" conversion factor has deemphasized electrical energy consumption and increased the emphasis of heating fuel consumption in the determination of total energy consumption. From an energy management standpoint, this shift makes it easier to attain energy reduction goals since changes in heating fuel consumption would now be reflected as larger changes in total energy consumption, and changes in electrical energy consumption would now be reflected as smaller changes in total energy consumption on a percentage basis.

The change to the "site" conversion factor also had the effect of improving the accuracy of the new equations and, in some cases, allowed USACERL to develop suitable equations where none had been possible previously. The latter result was due to the fact that regression equations developed from highly correlated data (e.g., for heating fuel) exhibit high values of correlation coefficient, whereas those developed from data having uncorrelated variations with time (e.g., electrical energy) exhibit much lower values of

[5]DEPPM 86-3.
*1 Btu = 1.055 kJ.

correlation coefficient. Since total energy consumption is calculated by summing both the highly correlated heating fuel consumption and the poorly correlated electrical energy consumption, the accuracy of regression equations developed for total energy consumption depends on the relative contributions made by heating fuel and electrical energy to the total value. The change to the "site" conversion factor increased the relative contribution of heating fuel to the total consumption, thus increasing the fraction of total energy consumption that was highly correlated with HDD and producing values of correlation coefficient which were much higher than those obtained with the "source" factor.

Problems Associated With Fixed Database Regression Analysis

The equations that had been developed previously for AMCCOM installations were based on data for the range FY75 to FY82, whereas those developed for DESCOM installations covered the data range FY75 to FY83. All data within these respective ranges were used in the regression analyses. This approach works well, provided changes in consumption pattern are relatively minor throughout the data range. If so, then this approach is preferred since, as was noted in Chapter 2, accuracy of the equation is increased by using the largest number of data points possible consistent with obtaining reasonable values of R^2. However, that was not the case for several installations, and the regression equations obtained for them exhibited low values of correlation coefficient.

A particular case in point is that of the Volunteer Army Ammunition Plant (AAP). Figure 1* is a graph of contractor LBRFRC at Volunteer AAP as a function of time over the FY75 to FY82 data range. It is seen that the contractor LBRFRC decreased considerably over this data range. In fact, Volunteer AAP went from an active to an inactive status during this time period. The regression equation obtained based on the entire data range had a very low correlation coefficient. A far more accurate equation would have been obtained had the data range used in the analysis been limited to a time period over which only minor changes in consumption pattern occurred, such as the range FY80 to FY82. EFAS was therefore developed to allow the data range used in the regression analysis to vary in such a way that the resulting regression equation is based on the data range producing the maximum value of R^2. Chapter 4 contains a detailed description of the algorithm by which this step is done.

As noted earlier, the AMC HQ Energy Office used the old equations during FY84 and FY85 to assess the effectiveness of energy conservation measures. Presumably, the equations would have continued to be used for energy management had they not been rendered invalid by the change to the "site" conversion factor for electrical energy consumption. The use of equations that characterize FY82 (for AMCCOM installations) or FY83 (for DESCOM installations) consumption patterns for predicting energy usage in all subsequent years would be practical only if no changes in energy consumption patterns were anticipated. Since the driving force behind EFAS development was to provide energy managers a tool with which they could assess the effectiveness of energy conservation efforts toward attaining the Army's energy goals, it is clear that significant changes in energy consumption patterns with time must be anticipated. Therefore, the utility of fixed database regression equations would decrease from year to year. The disparity between these equations and actual energy consumption patterns could be quite considerable by the time the target year FY95 is reached. This reasoning led to the

*Figures and tables are located at the end of each chapter.

requirement that EFAS provide the ability to update the installation regression equations as new data become available. Details on updating the regression equations are presented in Chapter 4.



Figure 1. Contractor labor force variation at Volunteer AAP.

4 EFAS DATABASE AND FEATURES

Database

The EFAS database, as provided to the user, contains pertinent monthly data for 59 AMC installations from FY75 to FY86. For convenience, the 59 installations are grouped into four categories: AMCCOM, DESCOM, TECOM, and Other Installations. In all cases, total facilities energy consumption (MBtu) and HDD data are provided. In addition, CDD and/or LBRFRC data are included for installations where these independent variables have been determined to be significant.

DEIS facilities energy consumption and LBRFRC data were supplied by AMC HQ. Weather data (HDD, CDD) were obtained from National Oceanic and Atmospheric Administration (NOAA) weather stations located near the individual installations. Tables 1 through 4 list the installations and their associated weather station locations for AMCCOM, DESCOM, TECOM, and Other Installations, respectively. The database can be updated manually using an EFAS option or, with the exception of LBRFRC, can be downloaded from the Army DEIS Data Entry System (ADDS) by means of an ADDS/EFAS interface supplied with EFAS.

Also included in the EFAS database are sets of equations obtained by multiple regression analysis which characterize the energy consumption patterns at a given installation for given fiscal years. The data range on which a particular equation is based extends from some starting fiscal year through the end of the fiscal year for which the equation represents the energy consumption pattern. The method by which the starting fiscal year is determined is discussed below under **Updating the Regression Equations.** Equations that characterize the energy consumption pattern for a given fiscal year are used to predict energy consumption for the following fiscal year (e.g., the equation used to predict energy consumption for FY87 is based on a data range through FY86). All regression equations contained in the EFAS database are of the general form:

$$MBtu = B_0 + B_1 \cdot HDD + B_2 \cdot CDD + B_3 \cdot LBRFRC \qquad \text{[Eq 7]}$$

In many cases, the coefficients B_2 and/or B_3 are equal to zero, indicating that CDD and/or LBRFRC were not found to be significant independent variables at that installation. Prediction equations for FY86 (based on data through FY85), the associated values of R^2, and the data range on which each equation is based are given in Tables 5 through 8 for AMCCOM, DESCOM, TECOM, and Other Installations, respectively. The equivalent information for FY87 (based on data through FY86) is given in Tables 9 through 12. Prediction equations for any given fiscal year are stored in the EFAS database to allow for comparisons of energy consumption patterns from year to year.

Updating the Regression Equations

EFAS has an option for calculating new regression equations. These new equations are calculated automatically when this option is chosen if additional data constituting a full fiscal year have been added to the database. Existing regression equations can also be recalculated for a given fiscal year if necessary. This would be the case if pertinent data were edited after the regression equation had been calculated. The regression equation and the associated value of R^2 for a particular installation and fiscal year are

initially determined based on the data range FY75 to the fiscal year of interest. The first 12 data points (corresponding to FY75) are then discarded and another regression equation and associated value of R^2 are calculated based on the abbreviated data range (FY76 to the fiscal year of interest). The data corresponding to FY76 are then discarded and another regression equation and associated value of R^2 determined based on the data range FY77 to the fiscal year of interest. This process of discarding data for the least recent fiscal year and recalculating the regression equation and associated value of R^2 continues until the abbreviated database contains only the most recent 3 years of data (the fiscal year of interest and the two previous fiscal years).

Next, the values of R^2 for the set of equations thus generated are compared, and the equation corresponding to the largest value of R^2 is entered into the database for use in predicting energy consumption for the following fiscal year. The value of R^2 and the data range associated with this equation are also stored in the database. The requirement that the regression equation be based on at least 3 years' data was added to EFAS to minimize the standard error. The fact that the associated data range always includes the most recent data allows the regression equations to account for changes in energy consumption patterns over time. It should be noted, however, that a time lag of 1 to 3 years will occur before the regression equations will be able to adequately account for drastic changes in energy consumption patterns.

EFAS Output

EFAS output consists of initial energy consumption predictions or "goals," adjusted energy consumption goals, and the percentage difference between adjusted energy consumption goals and actual energy consumption for any given fiscal year. Output is available for individual installations, individual MSCs, and all of AMC on monthly, quarterly, and annual bases.

Results of installation regression equations for which the associated values of R^2 are less than 0.5 are not included in MSC and AMC summary reports. Initial energy consumption goals are determined using 30-year average weather data and projected contractor LBRFRC data in the regression equations. Projected contractor LBRFRC values for any given month are initially set equal to the average LBRFRC values for the corresponding fiscal quarter of the preceding fiscal year for the particular installation. These values can be edited as contractor-supplied LBRFRC projections become available. Adjusted energy consumption goals are calculated by using actual weather and LBRFRC data in the regression equations as they become available.

Table 1

NOAA Weather Station Locations—AMCCOM Installations

Installation	Weather Station
Badger AAP*	Madison, WI
Cornhusker AAP	Grand Island, NB
Hawthorne AAP	Bishop, CA
Holston AAP	Bristol, TN
Indiana AAP	Louisville, KY
Iowa AAP	Peoria, IL
Joliet AAP	Chicago (O'Hare), IL
Kansas AAP	Wichita, KS
Lake City AAP	Kansas City, MO
Lone Star AAP	Shreveport, LA
Longhorn AAP	Shreveport, LA
Louisiana AAP	Shreveport, LA
McAlester AAP	Tulsa, OK
Milan AAP	Memphis, TN
Mississippi AAP	New Orleans, LA
Newport AAP	Indianapolis, IN
Picatinny Arsenal	Newark, NJ
Pine Bluff Arsenal	Little Rock, AR
Radford AAP	Roanoke, VA
Ravenna AAP	Akron, OH
Riverbank AAP	Stockton, CA
Rock Island Arsenal	Moline, IL
Rocky Mountain Arsenal	Denver, CO
Scranton AAP	Scranton, PA
Sunflower AAP	Kansas City, MO
Twin Cities AAP	Minneapolis-St. Paul, MN
Volunteer AAP	Chattanooga, TN
Watervliet Arsenal	Albany, NY

*AAP = Army Ammunition Plant.

Table 2

NOAA Weather Station Locations—DESCOM Installations

Installation	Weather Station
Anniston AD*	Birmingham, AL
Corpus Christi AD	Corpus Christi, TX
Fort Wingate DA**	Albuquerque, NM
Letterkenny AD	Harrisburg, PA
Lexington-Bluegrass AD	Lexington, KY
New Cumberland AD	Harrisburg, PA
Pueblo DA	Pueblo, CO
Red River AD	Shreveport, LA
Sacramento AD	Sacramento, CA
Savanna DA	Moline, IL
Seneca AD	Syracuse, NY
Sharpe AD	Stockton, CA
Sierra AD	Reno, NV
Tobyhanna AD	Scranton, PA
Tooele AD	Salt Lake City, UT
Umatilla DA	Pendleton, OR

*AD = Army Depot.
**DA = Depot Activity.

Table 3

NOAA Weather Station Locations—TECOM Installations

Installation	Weather Station
Aberdeen PG*	Baltimore, MD
Dugway PG	Salt Lake City, UT
Jefferson PG	Indianapolis, IN
White Sands MR**	Roswell, NM
Yuma PG	Yuma, AZ

*PG = Proving Ground.
**MR = Missile Range.

Table 4

NOAA Weather Station Locations—Other Installations

Installation	Weather Station
Detroit Arsenal	Detroit, MI
Fort Monmouth	Newark, NJ
Harry Diamond Labs	Washington, DC
Lima Army Tank Plant	Dayton, OH
Materials Technology Lab	Boston, MA
Natick RD&E Center	Boston, MA
Pontiac Storage Activity	Detroit, MI
Redstone Arsenal	Huntsville, AL
St. Louis Area Support Center	St. Louis, MO
Stratford Army Engine Plant	Bridgeport, CT

Table 5

EFAS FY86 Regression Equations—AMCCOM Installations

General Equation: $MBtu = B_0 + B_1 \cdot HDD + B_2 \cdot CDD + B_3 \cdot LBRFRC$

Installation	B_0	B_1	B_2	B_3	R^2	FY Range
Badger AAP*	885.52	7.37	0	-0.69	0.9073	83-85
Cornhusker AAP	255.09	4.14	0	0	0.6777	75-85
Hawthorne AAP	5004.66	44.42	0	0	0.8601	83-85
Holston AAP	-85618.75	90.43	0	318.11	0.8665	83-85
Indiana AAP	4340.60	37.45	0	0	0.9281	82-85
Iowa AAP	20395.53	90.56	0	0	0.9572	83-85
Joliet AAP	-95797.80	27.72	0	334.62	0.8932	76-85
Kansas AAP	4012.58	19.44	0	0	0.9152	79-85
Lake City AAP	25611.92	54.00	0	13.16	0.8867	80-85
Lone Star AAP	36362.28	81.25	0	0	0.8442	83-85
Longhorn AAP	18912.25	39.39	0	16.56	0.8560	80-85
Louisiana AAP	-18445.21	47.01	0	42.63	0.8423	77-85
McAlester AAP	7460.96	50.65	0	0	0.8454	75-85
Milan AAP	8579.67	48.61	0	0	0.9377	80-85
Mississippi AAP	19611.56	4.17	0	0	0.0011	82-85
Newport AAP	1740.64	12.57	0	0	0.9516	83-85
Picatinny Arsenal	74923.40	106.43	0	0	0.8796	83-85
Pine Bluff Arsenal	27217.08	43.76	0	0	0.7351	83-85
Radford AAP	-137455.20	185.38	0	142.66	0.8194	75-85
Ravenna AAP	-1085.04	9.73	0	15.08	0.8847	83-85
Riverbank AAP	9462.42	-2.90	0	0	0.0222	83-85
Rock Island Arsenal	51275.55	70.28	0	0	0.9554	82-85
Rocky Mountain Arsenal	10666.94	33.68	0	0	0.7926	83-85
Scranton AAP	32867.99	22.45	0	0	0.6811	83-85
Sunflower AAP	-135085.80	41.97	0	309.45	0.7998	82-85
Twin Cities AAP	10853.61	37.21	0	82.88	0.9364	75-85
Volunteer AAP	1583.90	1.31	0	-3.01	0.9174	83-85
Watervliet Arsenal	20713.55	42.44	0	0	0.9459	81-85

*AAP = Army Ammunition Plant.

Table 6

EFAS FY86 Regression Equations—DESCOM Installations

General Equation: $MBtu = B_0 + B_1 \cdot HDD + B_2 \cdot CDD + B_3 \cdot LBRFRC$

Installation	B_0	B_1	B_2	B_3	R^2	FY Range
Anniston AD*	34719.12	74.82	0	0	0.9241	83-85
Corpus Christi AD	36052.38	42.92	9.58	0	0.2435	83-85
Fort Wingate DA**	498.57	2.98	0	0	0.7208	83-85
Letterkenny AD	24338.51	49.77	9.03	0	0.8732	81-85
Lexington-Bluegrass AD	-321.98	35.87	0	4.96	0.8786	81-85
New Cumberland AD	14440.52	55.07	0	0	0.9504	81-85
Pueblo DA	7568.77	22.67	0	0	0.8734	83-85
Red River AD	-79309.78	89.36	0	20.30	0.9088	82-85
Sacramento AD	11988.74	28.31	0	0	0.6594	83-85
Savanna DA	731.79	16.99	0	0	0.9748	82-85
Seneca AD	4473.86	18.57	0	0	0.9626	82-85
Sharpe AD	8774.43	9.63	0	-3.98	0.9226	83-85
Sierra AD	3969.54	14.69	0	0	0.8886	81-85
Tobyhanna AD	16325.43	63.66	0	0	0.9343	81-85
Tooele AD	21222.83	57.37	0	0	0.8671	81-85
Umatilla DA	181.62	6.38	0	0	0.6431	81-85

*AD = Army Depot.
**DA = Depot Activity.

Table 7

EFAS FY86 Regression Equations—TECOM Installations

General Equation: $MBtu = B_0 + B_1 \cdot HDD + B_2 \cdot CDD + B_3 \cdot LBRFRC$

Installation	B_0	B_1	B_2	B_3	R^2	FY Range
Aberdeen PG*	109024.70	260.53	0	0	0.9669	83-85
Dugway PG	17831.27	21.39	0	0	0.6019	81-85
Jefferson PG	3569.36	6.73	-3.20	0	0.6925	81-85
White Sands MR**	38196.00	63.37	0	0	0.9364	83-85
Yuma PG	7857.69	14.44	6.44	0	0.3204	83-85

*PG = Proving Ground.
**MR = Missile Range.

Table 8

EFAS FY86 Regression Equations—Other Installations

General Equation: $MBtu = B_0 + B_1 \cdot HDD + B_2 \cdot CDD + B_3 \cdot LBRFRC$

Installation	B_0	B_1	B_2	B_3	R^2	FY Range
Detroit Arsenal	31894.17	61.79	0	0	0.8720	83-85
Fort Monmouth	41597.07	94.13	0	0	0.9146	83-85
Harry Diamond Labs	16890.95	11.89	0	0	0.8903	83-85
Lima Army Tank Plant	-39839.96	33.33	0	20.30	0.8894	83-85
Materials Technology Lab	3241.77	16.15	0	0	0.8174	83-85
Natick RD&E Center	9016.26	7.15	0	0	0.8470	83-85
Pontiac Storage Activity	251.64	-1.81	0	0	0.0029	82-85
Redstone Arsenal	66459.80	211.51	0	0	0.8045	81-85
St. Louis Area Support Center	5710.92	22.60	0	0	0.7324	83-85
Stratford Army Engine Plant	49463.45	29.16	0	0	0.3596	81-85

Table 9

EFAS FY87 Regression Equations—AMCCOM Installations

General Equation: $MBtu = B_0 + B_1 \cdot HDD + B_2 \cdot CDD + B_3 \cdot LBRFRC$

Installation	B_0	B_1	B_2	B_3	R^2	FY Range
Badger AAP*	-598.16	6.50	0	3.83	0.8565	84-86
Cornhusker AAP	83.96	2.77	0	0	0.8673	84-86
Hawthorne AAP	4191.48	41.99	0	0	0.8297	83-86
Holston AAP	-79853.47	85.65	0	315.13	0.8485	83-86
Indiana AAP	3825.19	34.50	0	0	0.9597	84-86
Iowa AAP	21132.66	85.66	0	0	0.9560	84-86
Joliet AAP	-93673.16	27.28	0	331.00	0.8892	76-86
Kansas AAP	4535.54	19.64	0	0	0.8871	79-86
Lake City AAP	24319.56	54.80	0	13.72	0.8824	80-86
Lone Star AAP	40905.99	85.60	0	0	0.8163	84-86
Longhorn AAP	-43584.51	42.83	0	82.45	0.8602	84-86
Louisiana AAP	-11929.75	47.66	0	34.53	0.7723	77-86
McAlester AAP	7834.18	50.57	0	0	0.8231	75-86
Milan AAP	8863.24	47.92	0	0	0.9354	80-86
Mississippi AAP	6282.14	5.04	0	29.70	0.3929	84-86
Newport AAP	1738.30	12.53	0	0	0.9550	83-86
Picatinny Arsenal	73557.11	100.97	0	0	0.8702	84-86
Pine Bluff Arsenal	34410.44	45.84	0	0	0.6414	84-86
Radford AAP	-123120.70	188.77	0	136.96	0.8067	75-86
Ravenna AAP	2420.38	8.20	0	-2.09	0.8947	84-86
Riverbank AAP	11782.02	1.15	0	0	0.0032	84-86
Rock Island Arsenal	53759.50	69.95	0	0	0.9392	82-86
Rocky Mountain Arsenal	8921.60	30.66	0	0	0.7709	84-86
Scranton AAP	36314.49	22.13	0	0	0.5322	83-86
Sunflower AAP	-158933.59	46.51	0	350.97	0.7993	82-86
Twin Cities AAP	10563.38	36.41	0	83.91	0.9310	75-86
Volunteer AAP	859.31	1.42	0	0.62	0.9309	84-86
Watervliet Arsenal	22436.35	42.51	0	0	0.9509	84-86

*AAP = Army Ammunition Plant.

Table 10

EFAS FY87 Regression Equations—DESCOM Installations

General Equation: $MBtu = B_0 + B_1 \cdot HDD + B_2 \cdot CDD + B_3 \cdot LBRFRC$

Installation	B_0	B_1	B_2	B_3	R^2	FY Range
Anniston AD*	35406.44	72.64	0	0	0.9253	83-86
Corpus Christi AD	35262.54	50.49	13.22	0	0.4280	84-86
Fort Wingate DA**	396.87	2.79	0	0	0.6637	83-86
Letterkenny AD	20040.42	47.28	12.72	0	0.8894	84-86
Lexington-Bluegrass AD	-321.98	35.87	0	4.96	0.8786	81-86
New Cumberland AD	14004.74	53.01	0	0	0.9459	84-86
Pueblo DA	6750.78	20.91	0	0	0.8247	84-86
Red River AD	-12578.78	87.79	0	9.29	0.9029	81-86
Sacramento AD	11902.24	27.85	0	0	0.6358	84-86
Savanna DA	681.27	16.94	0	0	0.9740	82-86
Seneca AD	4389.45	18.16	0	0	0.9674	84-86
Sharpe AD	15318.90	9.22	0	-8.41	0.8354	83-86
Sierra AD	3901.85	15.23	0	0	0.8910	84-86
Tobyhanna AD	15587.14	64.93	0	0	0.9378	81-86
Tooele AD	23701.11	58.91	0	0	0.8808	84-86
Umatilla DA	207.82	5.68	0	0	0.8737	84-86

*AD = Army Depot.
**DA = Depot Activity.

Table 11

EFAS FY87 Regression Equations—TECOM Installations

General Equation: $MBtu = B_0 + B_1 \cdot HDD + B_2 \cdot CDD + B_3 \cdot LBRFRC$

Installation	B_0	B_1	B_2	B_3	R^2	FY Range
Aberdeen PG*	112958.10	259.65	0	0	0.9746	84-86
Dugway PG	12350.00	24.80	0	0	0.8623	84-86
Jefferson PG	2409.71	7.37	-2.48	0	0.7392	81-86
White Sands MR**	38413.55	61.44	0	0	0.9346	83-86
Yuma PG	9005.48	13.49	6.28	0	0.5086	84-86

*PG = Proving Ground.
**MR = Missile Range.

Table 12

EFAS FY87 Regression Equations—Other Installations

General Equation: $MBtu = B_0 + B_1 \cdot HDD + B_2 \cdot CDD + B_3 \cdot LBRFRC$

Installation	B_0	B_1	B_2	B_3	R^2	FY Range
Detroit Arsenal	39021.48	65.66	0	0	0.8950	84-86
Fort Monmouth	43673.79	84.04	0	0	0.9115	84-86
Harry Diamond Labs	16827.36	11.69	0	0	0.8566	83-86
Lima Army Tank Plant	7015.67	28.52	0	6.43	0.8440	84-86
Materials Technology Lab	2657.44	18.19	0	0	0.8535	84-86
Natick RD&E Center	8561.44	7.48	0	0	0.8569	84-86
Pontiac Storage Activity	299.28	1.35	0	0	0.0006	83-86
Redstone Arsenal	169432.50	206.78	0	0	0.7991	81-86
St. Louis Area Supt Ctr	5150.97	21.39	0	0	0.7097	84-86
Stratford Army Engine Plant	50086.82	27.47	0	0	0.3428	81-86

5 EFAS AS AN ENERGY MANAGEMENT TOOL

Energy Consumption Goal-Setting and Monitoring

The primary use for EFAS is in energy consumption goal-setting and monitoring. Installation adjusted goals for any given fiscal year characterize the energy consumption pattern through the previous fiscal year. Since the effects of weather and LBRFRC variations have been filtered out through multiple regression analysis, it is expected that actual energy consumption would be slightly less than, or at least no greater than, the adjusted goal values provided no significant change in installation square footage has occurred. This result would indicate a decrease, or in the limit, no change, in the energy consumption pattern consistent with progress toward overall energy reduction goals.

If installation square footage has seen a significant change within the last year, current actual energy consumption should be divided by current fiscal year square footage, and adjusted goals divided by previous fiscal year square footage before the comparisons are made. Any significantly large differences between actual consumption and adjusted goals should raise a flag to the energy manager to investigate the causes for this difference. Occasionally, these differences may occur for a given installation in a given month simply due to inherent inaccuracies in the regression equations. However, statistical theory indicates that the errors associated with regression equations are normally distributed with a mean of zero. Hence, while a large error may be observed for a given installation in a given month, errors associated with the monthly adjusted goals should tend to cancel out as values are summed over time or over installations if no change in consumption pattern occurs. For this reason, differences between actual consumption and adjusted goals for a given installation on an annual basis, or for an aggregate of installations (e.g., a large MSC) on a monthly basis, would most likely indicate actual changes in energy consumption patterns.

Building Energy Glide Path Determination

Building energy reduction goals call for a decline in existing building energy consumption (Btu per square foot) of 8 percent by FY95 using FY85 as the base year. An initial glide path for use in energy management could be formed by assuming an annual energy reduction of 0.8 percent of the FY85 building energy consumption each year. Subsequent actual building energy consumption values could then be compared with the glide path values for evaluating progress toward goal attainment. This approach, however, would not be useful in evaluating the effectiveness of energy conservation efforts because it does not take into consideration differences in energy consumption due to varying weather and production levels between current and base fiscal years.

A much more reasonable approach from the standpoint of energy management would be to establish the glide path based on an annual reduction of 0.8 percent in energy consumption pattern. The annual energy consumption goals would be the same as in the previous case, but the actual energy consumption values would be adjusted to account for differences in weather and production levels between current and base fiscal years prior to comparison with glide path values. This section describes how EFAS can be used to make these adjustments in actual energy consumption for glide path comparisons. A sample calculation is then presented.

Energy consumption adjusted goals for any month of the current fiscal year can be expressed as:

$$[MBtu]_{CY} = (B_0)_{CY} + (B_1)_{CY} \cdot (HDD)_{CY} + (B_2)_{CY} \cdot (CDD)_{CY} + (B_3)_{CY} \cdot (LBRFRC)_{CY} \qquad \text{[Eq 8]}$$

where the subscript "CY" indicates values for the current fiscal year. An equivalent FY85 energy consumption adjusted goal ($[MBtu]_{EQ}$) can be defined as:

$$[MBtu]_{EQ} = (B_0)_{CY} + (B_1)_{CY} \cdot (HDD)_{85} + (B_2)_{CY} \cdot (CDD)_{85} + (B_3)_{CY} \cdot (LBRFRC)_{85} \qquad \text{[Eq 9]}$$

where the subscript "85" indicates values for the base year FY85. $[MBtu]_{EQ}$ represents the energy that would have been consumed in the current year had the weather and production levels been identical to those of FY85. Note that the values of the regression coefficients used in both Equations 8 and 9 correspond to the current fiscal year predictive equation. If process energy is managed separately from building energy, or if it is desired to make adjustments only for weather differences, then $[MBtu]_{EQ}$ should be calculated as:

$$[MBtu]_{EQ} = (B_0)_{CY} + (B_1)_{CY} \cdot (HDD)_{85} + (B_2)_{CY} \cdot (CDD)_{85} + (B_3)_{CY} \cdot (LBRFRC)_{CY} \qquad \text{[Eq 10]}$$

An adjustment factor ([AF]) can be defined as:

$$[AF] = [MBtu]_{EQ} / [MBtu]_{CY} \qquad \text{[Eq 11]}$$

and a correlation factor [CF] can be defined as:

$$[CF] = 1 / [AF] + (1 - 1 / [AF]) \cdot R^2 \qquad \text{[Eq 12]}$$

where R^2 is the correlation coefficient for the current fiscal year. An adjusted energy consumption value ($[ENERGY]_{ADJ}$) for use in glide path comparison can then be calculated as:

$$[ENERGY]_{ADJ} = [CF] \cdot [AF] \cdot [ENERGY]_{CY} \qquad \text{[Eq 13]}$$

where $[ENERGY]_{CY}$ is the actual energy consumption for the current fiscal year. The reason for using the correlation factor in Equation 13 is to compensate for the accuracy

of the regression equation. Its effect is to apply the entire adjustment factor for the case of perfect correlation ($R^2 = 1$) and to decrease the amount of adjustment linearly as R^2 decreases. For total lack of correlation ($R^2 = 0$), no adjustment is made. If process energy is managed separately from building energy, it should be subtracted from $[ENERGY]_{ADJ}$ prior to comparison with building energy glide path values.

Sample Calculation

Actual energy consumption at Indiana AAP for the base year FY85 was 188,340 MBtu. For FY86, the actual energy consumption was 181,461 MBtu. This figure represents a decrease of 3.65 percent from base year usage. Assuming for this example that no significant changes in square footage occurred between FY85 and FY86, the glide path goal would be an 0.8 percent reduction. The multiple regression predictive equation for Indiana AAP for FY86 was determined by EFAS to be:

$$MBtu = 4340.60 + 37.45 \cdot HDD \qquad \text{[Eq 14]}$$

with a corresponding correlation coefficient (R^2) of 0.9281. This equation indicates that HDD is the only significant independent variable at this installation ($B_2 = B_3 = 0$). The total number of HDDs at Indiana AAP was 4168 during FY85 and 4037 during FY86. Hence, some of the 3.65 percent reduction in energy consumption can be attributed to a decreased number of HDDs, whereas the rest can be attributed to a change in energy consumption pattern. It is the latter quantity that corresponds to the adjusted energy consumption and that should be used for comparison with the glide path value. Monthly values of HDD for FY85 and FY86, along with the corresponding values of $[MBtu]_{EQ}$ and $[MBtu]_{86}$ calculated using Equation 14, are given in Table 13. On an annual basis, the values of $[MBtu]_{EQ}$ and $[MBtu]_{86}$ are 208,179 MBtu and 203,290 MBtu, respectively. The adjustment factor is calculated using Equation 11:

$$[AF] = 208179 / 203290 = 1.024$$

The correlation factor is calculated using Equation 12:

$$[CF] = 1 / 1.024 + (1 - 1 / 1.024) \cdot 0.9281 = 0.998$$

The adjusted energy consumption is calculated using Equation 13:

$$[ENERGY]_{ADJ} = 0.998 \cdot 1.024 \cdot 181461 = 185444 \text{ MBtu}$$

This value indicates a 1.54 percent reduction in energy consumption from base year FY85 attributable to changes in energy consumption pattern (i.e., as a result of energy conservation measures). Most of the original 3.65 percent energy reduction (2.11 percent) is attributable to the difference in the number of HDDs. Figure 2 shows the glide path for Indiana AAP and compares the actual and adjusted energy consumption.

Table 13

Glide Path Comparison Data—Indiana AAP

Month	FY85 HDD	FY86 HDD	$[MBtu]_{EQ}$	$[MBtu]_{86}$
OCT	84	160	7486	10333
NOV	623	347	27672	17337
DEC	584	1067	26211	44304
JAN	1222	941	50105	39585
FEB	896	696	37896	30409
MAR	458	516	21493	23667
APR	180	224	11082	12730
MAY	52	69	6288	6925
JUN	16	0	4940	4341
JUL	0	0	4341	4341
AUG	0	12	4341	4790
SEP	53	5	6325	4528
TOTAL	4168	4037	208179	203290



Figure 2. FY86 energy consumption and glide path for Indiana AAP.

6 CONCLUSIONS AND RECOMMENDATIONS

USACERL has developed EFAS--an automated tool to help AMC energy managers determine their organization's progress in achieving energy conservation goals. The system uses multiple regression analysis to provide more realistic results than possible using a direct comparison with the base year consumption.

The multiple regression analysis technique has been shown to provide accurate models of energy consumption patterns for most installations within AMC. EFAS uses this technique to provide energy consumption goals that can be compared with actual energy consumption values for energy monitoring and management. EFAS can make energy glide path comparisons on the basis of percentage reduction of energy consumption pattern from the base year. The success of EFAS is evident in the high R^2 values obtained during implementation (see the tables).

It is recommended that AMC use EFAS as part of its MACOM-wide energy management program. It is further recommended that: (1) other MACOMs consider developing similar systems for use in their energy management programs, (2) energy consumption goals for the Army be based on reductions in energy consumption pattern rather than actual consumption, and (3) the glide path comparison adjustment technique be allowed to be used for energy consumption reporting to DEIS. The DEIS report currently requires the use of actual consumption data.

Although EFAS is specific for AMC HQ's needs, the multiple regression concept and glide path adjustment technique described in this report are potentially useful in other energy management applications. Development of a system like EFAS for other MACOMS would be site-specific, requiring research to identify the unique independent variables.

USACERL DISTRIBUTION

Chief of Engineers
ATTN: CEIM-SL
ATTN: CECC-P
ATTN: CECW
ATTN: CECW-O
ATTN: CECW-P
ATTN: CECW-RR
ATTN: CEEC
ATTN: CEEC-C
ATTN: CEEC-E
ATTN: CERD
ATTN: CERD-C
ATTN: CERD-M
ATTN: CERM
ATTN: DAEN-ZCE
ATTN: DAEN-ZCI
ATTN: DAEN-ZCM
ATTN: DAEN-ZCZ

USAEHSC, ATTN: Library 22060
ATTN: DET III 79906
ATTN: CEHSC-FU 22060

US Army Engineer Districts
ATTN: Library (41)

US Army Engineer Divisions
ATTN: Library (13)

US Army Europe
AEAEN-ODCS/Engr (2) 09403
AEUES 09081
V Corps
ATTN: DEH (12)
VII Corps
ATTN: DEH (16)
21st Support Command
ATTN: DEH (12)
USA Berlin
ATTN: DEH (10)
USASETAF
ATTN: DEH
Allied Command Europe (ACE)
ATTN: ACSGEB/Engr
ATTN: SHIHG/Engr

8th USA, Korea (19)
ROK/US Combined Forces Command 96301
ATTN: EUSA HHC CFC/Engr

USA Japan (USARJ)
ATTN: DCSEN 96343
ATTN: Fac Engr 96343
ATTN: DEH-Okinawa 96331

416th Engineer Command 60623
ATTN: Facilities Engr

US Military Academy 10966
ATTN: Facilities Engineer
ATTN: Dept of Geography & Computer Science
ATTN: MAEN-A

AMMRC 02172
ATTN: DRXMR-WE
ATTN: DRXMR-AF

USA AMCCOM 61299
ATTN: AMSMC-RI
ATTN: AMSMC-IS

AMC - Dir., Inst., & Servc
ATTN: DEH (23)

DLA ATTN: DLA WI 22304

DNA ATTN: NADS 20305

FORSCOM
FORSCOM Engr, ATTN: Spt. Det.
ATTN: DEH (28)

HSC
Ft. Sam Houston AMC 78234
ATTN: HSLO-F
Fitzsimons AMC 80045
ATTN: HSHG-DEH
Walter Reed AMC 20307
ATTN: Facilities Engineer

INSCOM - Ch, Instl. Div
ATTN: Facilities Engineer (5)

MDW, ATTN: DEH (3)

MTMC
ATTN: MT-LOF 20315
ATTN: Facilities Engineer (3)

NARADCOM, ATTN: DRDNA-F 01760

TARCOM, Fac. Div. 48090

TRADOC
HQ, TRADOC, ATTN: ATEN-DEH
ATTN: DEH (18)

TSARCOM, ATTN: STSAS-F 63120

USAIS, ATTN: Facilities Engr (4)

WESTCOM
ATTN: DEH, Ft. Shafter 96858
ATTN: APEN-A

SHAPE 09055
ATTN: Surv. Section, CCB-OPS
Infrastructure Branch, LANDA

HQ USEUCOM 09128
ATTN: ECJ 4/7-LOE

FORT BELVOIR, VA 22060 (11)
ATTN: Canadian Liaison Officer
ATTN: British Liaison Officer
ATTN: Australian Liaison Officer
ATTN: French Liaison Officer
ATTN: German Liaison Officer
ATTN: Water Resources Support Ctr
ATTN: Engr Studies Center
ATTN: Engr Topographic Lab.
ATTN: ATZA-TE-SU
ATTN: ATZA-TE-EM
ATTN: STRBE-BLURE

CECRL, ATTN: Library 03755

CEWES, ATTN: Library 39180

HQ, XVIII Airborn Corps
and Fort Bragg
ATTN: AFZA-FE-EE 28307

Area Engineer, AEDC-Area Office
Arnold Air Force Station, TN 37389

Chanute AFB, IL 61868
3345 CES/DE, Stop 27

Norton AFB, CA 92409
ATTN: AFRCE-MX/DE

AFESC, Tyndall AFB, FL 32403

NAVFAC
ATTN: Engineering Command (9)
ATTN: Division Offices (11)
ATTN: Naval Public Works Center (9)
ATTN: Naval Civil Engr Lab. (2)
ATTN: Naval Constr Battalion Ctr

NCEL
ATTN: Library, Code L08A 93043

Defense Technical Info. Center 22314
ATTN: DDA (2)

SETAF Engineer Design Office 09019

Engr Societies Library, NY 10017

Natl Guard Bureau Instl. Div 20310

US Govt Print Office 22304
Receiving Sect/Depository Copies (2)

US Army Env. Hygiene Agency
ATTN: HSHB-E 21010

National Bureau of Standards 20899

319
+70
02/89